



Certificate of Compliance

Certificate Number: LR 12730-352
KEMA Ref. 97.1913

Revision: LR 12730-367

Date Issued: May 7, 1997

Issued To: Siemens AG
Abt. ASI 2 GWA TPA
Werner von Siemens
Strasse 48
92220 AMBERG
Germany

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski
CSA Montreal

Signature

PRODUCTS

Contactors, open types, Series 3RT10, with the following ratings:

Voltage	Horsepower	
	1-ph	3-ph
115 V	1 hp	--
200 V	2 hp	3 hp
230 V	2 hp	3 hp
460 V	--	7 1/2 hp
575 V	--	10 hp
600 V	--	10 hp

Main Contacts: General Purpose Rating
600 Vac, 20 A

Auxiliary Contacts: A600/P600 for the basic device
A600/Q600 for the auxiliary contact block
240 V/10 A general purpose

Coil Ratings: 24 through 600 Vac
12 through 250 Vdc



Certificate of Compliance

Certificate Number: LR 12730-352
KEMA Ref. 97.1913

Revision: LR 12730-367

Date Issued: May 7, 1997

Notes:

- 1 The type designations may be completed with suffixes indicating contact arrangements, terminal design, mounting etc.
- 2 Certified as component for use only in Certified equipment where the acceptability of the combination is to be determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements
" " " " 14 - 95 - Industrial Control Equipment