

Our Ref: CR/JC

28 March 2003



Loctite UK Ltd
Watchmead
Welwyn Garden City
Hertfordshire
AL7 1JB

Dear Sir

WATER REGULATIONS ADVISORY SCHEME

"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

SEALANTS - SCREWED JOINTS - GENERAL 5510

Loctite 5331. White thread sealant. Cure for 96 hours at 22°C. For cold water and hot water use up to 85°C.

Test Report: M100813 & M102298/A, M102928

0210527


LOCTITE UK LTD

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory; this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". Approval of this product does not signify the approval of its mechanical or physical properties for any use.

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in October 2007.

Yours faithfully


Chris Ramsey (Miss)
Materials Administrator
Water Regulations Advisory Scheme

Water Regulations Advisory Scheme
Furn Gouse, Rose-Tann Industrial Estate,
Oxley, Covent, CV11 3JH, UK
Tel: 01455 249454 Fax: 01455 249251
E-mail: info@wras.co.uk Website: www.wras.co.uk

WRAS 04
Page 4 of 4
Page 4 of 4
Page 4 of 4