



# Certificate of Compliance

Certificate Number: LR 12730-372  
KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

Issued To: Siemens AG  
Abt. ASI 2 GWA TPA  
Werner von Siemens  
Strasse 48  
92220 AMBERG  
Germany

*The products listed below are eligible to bear the CSA Mark.*

Issued By: J. Pankowski  
CSA Montreal

Signature

## PRODUCTS

Across-the-Line Motor Starters, 3-ph 60 Hz, with integral ambient compensated, non replaceable thermal trip features and are suitable for providing overload protection with the following ratings:

3RV1.01., open type, 0.11 up to 12 A in 20 setting ranges.  
General purpose 12 A 600 Vac max 1/2 hp 115 Vac, 1½ hp 200 Vac, 2 hp 230 Vac  
1-ph; 3 hp 200/230 Vac, 7½ hp 460 Vac, 10 hp 575/600 Vac 3-ph.

## Notes:

- 1 The type designations may be completed with suffixes indicating electrical and mechanical details. Control terminal may be quick connect terminals.
- 2 The motor starters are Certified for mounting in industrial control panels, machine tool cavities, etc., where the final assembly is acceptable to the Canadian Standards Association.

**Certificate of Compliance**

Certificate Number: LR 12730-372

KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

---

**APPLICABLE REQUIREMENTS**

CAN/CSA-C22.2 No. 0 - M91 - General Requirements  
" " " " 14 - 95 - Industrial Control Equipment