SIEMENS

Data sheet 5SM3645-8



Residual current operated circuit breaker, 4-pole, type A, selective, In: 125 A, 300 mA, Un AC: 400 V $\,$

Model	
product brand name	SENTRON
product designation	RCCB
design of the product	Selective
product type designation	5SM3
General technical data	
number of poles	4
size of installation devices according to DIN 43880	1
mechanical service life (operating cycles) typical	10 000
short-circuit current rating	10 kA
switching function short-term delayed	No
overvoltage category	III
Supply voltage	
supply voltage for testing equipment minimum	100 V
value range of the supply voltage frequency	50 Hz
value range of the operating frequency	50 Hz
value range of the supply voltage at AC	400 V
Protection class	
protection class IP	IP20, if the distribution board is installed, with connected conductors
Switching capacity	
switching capacity current	
 according to EN 60898 rated value 	1.25 kA
 according to IEC 61008-1 rated value 	1.25 kA
Dissipation	
power loss [W]	
 for rated value of the current at AC in hot operating state per pole 	8.9 W
• maximum	26.7 W
Product details	
product feature silicon-free	Yes
product extension installable supplementary devices	Yes
Connections	
connectable conductor cross-section solid	
• minimum	2.5 mm²
• maximum	50 mm ²
connectable conductor cross-section stranded	
• minimum	2.5 mm²
• maximum	50 mm²
tightening torque with screw-type terminals	
• minimum	3 N·m

• maximum	4 N·m				
position of power supply cord	top or bottom				
Mechanical Design					
height	90 mm				
width	72 mm				
depth	77 mm				
installation depth	70 mm				
number of modular width units	4				
fastening method	DIN rail (REG)				
mounting position	any				
net weight	538 g				
Environmental conditions					
ambient temperature during operation					
• minimum	-25 °C				
• maximum	45 °C				
ambient temperature during storage minimum	-40 °C				
number of test cycles for environmental testing according to IEC 60068-2-30	28				
Approvals Certificates					
General Product Approval		Declaration of Conformity	other		
Confirmation Miscellaneous			<u>Miscellaneous</u>	Confirmation	

Dangerous Good Environment

<u>Transport Information</u> <u>Environmental Confirmation</u>

firmations

Further information

Siemens has decided to exit the Russian market (see here).

 $\underline{\text{https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business}}$

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

 $\underline{https://support.industry.siemens.com/cs/ww/en/view/109813875}$

 $Information-\ and\ Download center\ (Catalogs,\ Brochures,...)$

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SM3645-8

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SM3645-8

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ ...)$

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SM3645-8

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications

last modified: 8/15/2023 🖸