



# Certificate of Compliance

Certificate Number: LR 12730-364  
KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

Issued To: Siemens AG  
Abt. ASI 2 GWA TPA  
Werner von Siemens  
Strasse 48  
92220 AMBERG  
Germany

*The products listed below are eligible to bear the CSA Mark.*

Issued By: J. Pankowski  
CSA Montreal

Signature

## PRODUCTS

Contactors, open types, Series 3RT1044, 3RT1045, 3RT1046, with the following ratings:

Voltage	Horsepower 3RT1044	
	1-ph	3-ph
115 V	5 hp	--
200 V	10 hp	20 hp
230/240 V	15 hp	25 hp
460/480 V	--	50 hp
575 V	--	60 hp
600 V	--	60 hp



## Certificate of Compliance

Certificate Number: LR 12730-364

KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

<u>Voltage</u>	<u>Horsepower 3RT1045</u>	
	<u>1-ph</u>	<u>3-ph</u>
115 V	5 hp	--
200 V	15 hp	25 hp
230/240 V	15 hp	30 hp
460/480 V	--	60 hp
575 V	--	75 hp
600 V	--	75 hp

<u>Voltage</u>	<u>Horsepower 3RT1046</u>	
	<u>1-ph</u>	<u>3-ph</u>
115 V	7 1/2 hp	--
200 V	15 hp	30 hp
230/240 V	15 hp	30 hp
460/480 V	--	75 hp
575 V	--	100 hp
600 V	--	100 hp

Main Contacts: General Purpose  
- Type 3RT1044: 600 Vac 90 A  
- Type 3RT1045 or 3RT1046: 600 Vac 105 A

Auxiliary Contacts: A600/Q600 240 V/10 A general purpose  
Auxiliary contact blocks Type 3RH19 are top or side mounted

Coil Ratings: 24 through 600 Vac  
24 through 250 Vdc

### Notes:

- 1 The type designations may be completed with suffixes indicating contact arrangements, terminal design, mounting etc.
- 2 Certified as component for use only in Certified equipment where the acceptability of combination is to be determined by the Canadian Standards Association.

### APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements  
" " " " 14 - 95 - Industrial Control Equipment