## **DATASHEET - FAZ6-C2/1**



Miniature circuit breaker (MCB), 2 A, 1p, characteristic: C, 6 kA

Powering Business Worldwide

Part no. FAZ6-C2/1 239031 Catalog No. Alternate Catalog FAZ6-C2/1

Similar to illustration

## **Design verification as per IEC/EN 61439**

| Design vernication as per 1EG/EN 01433  |                  |   |  |
|---|------------------|---|--|
| Technical data for design verification  |                  |   |  |
| Rated operational current for specified heat dissipation  | In               | Α | 2  |
| Equipment heat dissipation, current-dependent   | P <sub>vid</sub> | W | 1.4  |
| IEC/EN 61439 design verification  |                  |   |  |
| 10.2 Strength of materials and parts  |                  |   |  |
| 10.2.2 Corrosion resistance   |                  |   | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  |                  |   | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                  |   | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ |                  |   | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                  |   | Meets the product standard's requirements.   |
| 10.2.5 Lifting  |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   |                  |   | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  |                  |   | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  |                  |   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   |                  |   | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  |                  |   | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |                  |   |  |
| 10.9.2 Power-frequency electric strength  |                  |   | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  |                  |   | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  |                  |   | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  |                  |   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating  |                  |   | Is the panel builder's responsibility. The specifications for the switchgear must observed.                                      |
| 10.12 Electromagnetic compatibility   |                  |   | Is the panel builder's responsibility. The specifications for the switch<br>gear must observed. $\label{eq:specification}$       |
| 10.13 Mechanical function   |                  |   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## **Technical data ETIM 7.0**

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB)

| (ecl@ss10.0.1-27-14-19-01 [AAB905014])                      |    |     |  |  |
|---|----|-----|--|--|
| Release characteristic                                      |    | С   |  |  |
| Number of poles (total)                                     |    | 1   |  |  |
| Number of protected poles                                   |    | 1   |  |  |
| Rated current   | А  | 2   |  |  |
| Rated voltage   | V  | 230 |  |  |
| Rated insulation voltage Ui                                 | V  | 440 |  |  |
| Rated impulse withstand voltage Uimp                        | kV | 4   |  |  |
| Rated short-circuit breaking capacity Icn EN 60898 at 230 V | kA | 6   |  |  |

| Rated short-circuit breaking capacity Icn EN 60898 at 400 V    | kA | ١  | 6        |
|--|----|----|----------|
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V | kA | 4  | 10       |
| Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V | kA | 4  | 10       |
| Voltage type   |    |    | AC       |
| Frequency  | Hz | 2  | 50 - 60  |
| Current limiting class   |    |    | 3        |
| Suitable for flush-mounted installation                        |    |    | No       |
| Concurrently switching N-neutral                               |    |    | No       |
| Over voltage category  |    |    | 3        |
| Pollution degree   |    |    | 2        |
| Additional equipment possible                                  |    |    | Yes      |
| Width in number of modular spacings                            |    |    | 1        |
| Built-in depth   | mn | m  | 70.5     |
| Degree of protection (IP)                                      |    |    | IP20     |
| Ambient temperature during operating                           | °C | ;  | -25 - 75 |
| Connectable conductor cross section multi-wired                | mn | m² | 1 - 25   |
| Connectable conductor cross section solid-core                 | mr | m² | 1 - 25   |
|  |    |    |          |