



Certificate of Compliance

Certificate Number: LR 12730-351
KEMA Ref. 97.1913

Revision: LR 12730-367

Date Issued: May 7, 1997

Issued To: Siemens AG
Abt. ASI 2 GWA TPA
Werner von Siemens
Strasse 48
92220 AMBERG
Germany

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski
CSA Montreal

Signature

PRODUCTS

Industrial Relay, Series 3RH1 open type, with the following ratings: 240 V 10 A general purpose. A600/P600 for the basic device, A600/Q600 for the auxiliary contact block.

Notes:

- 1 The type designations may be completed with suffixes indicating shape of contacts, terminal design, mounting etc.
- 2 Certified for use in equipment where the acceptability of the combination is to be determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements
" " " " 14 - 95 - Industrial Control Equipment