

Our Ref: HL/M1303083
Test Report: MAT/LAB 397G

27th November 2013

Calmag Yorkshire Ltd.
Riverview Buildings,
Bradford Road,
Riddlesden,
Keighley,
West Yorkshire,
BD20 5JH

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE) – COMPONENTS

5294

`Calmag PTFE thread seal tape`. White coloured PTFE tape. For use with water up to 85°C.


APPROVAL NUMBER: 1311525
APPROVAL HOLDER: CALMAG YORKSHIRE LTD.

The Scheme reserves the right to review approval. This approval is valid between November 2013 and November 2018.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme