Vol. 1 Sec. 15 Page 1 Issued: 5-29-87 File E67320 Revised: 6-22-01 and Report

DESCRIPTION

PRODUCT COVERED:

Component supplementary protectors, Cat. No. 8340 followed by F, G or T, followed by 0 through 9, followed by 0 through 9 or A through E, followed by 0 through 9, followed by C, D, G, K, N, P, Q, R, V, X or Z, followed by 0 through 9, followed by A through Z, followed by 0 through 9, followed by A through O, followed by O through 9 or A through Z, followed by G, H or K, followed by 0 through 9, followed by 1 through 5 or A or B, followed by 1 through 6, followed by current rating 0.02 A through 50 A inclusive and/or voltage rating 5 V dc through 80 V dc or 115 V ac through 240 V ac.

GENERAL:

These devices are 1, 2, 3 and 4 pole magnetic overcurrent protectors with or without hydraulic magnetic delay. These devices are intended for use in household and commercial appliances. They are provided with manual means of opening the circuit.

RATINGS:

Voltage - 250 V ac or 65 or 80 V dc, 50/60 Hz.

Main Contact Current - 0.02 - 50 A.

Auxiliary Circuit (When Provided) - 10 A, 250 V ac.

Maximum Short Circuit Interrupting:

For Type 8340-F and T

	Rated Current, A	AC 60/60 H: 75-80 Percent Single Phase			
*	0.02-30	3500	5000	5000	
		Rated Current, A		or 80 V Resisti Circuit Current	
		0.02-50		3500	

Vol. 1 Sec. 15 Page 2 File E67320

Issued: 5-29-87 and Report Revised: 6-22-01

For Type 8340-Gl And -G2

AC 60/50 Hz. 250 V

Rated	Power Factor 75-80 Percent	DC 65 or 80 V	
Current, A	Single Phase	Resistive	
0.02-30 40-50	3500	3500 3500	

ENGINEERING CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

Use - For use only in complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

These components have been judged on the basis of the required spacings in the Standard for Supplementary Protectors (UL 1077), Second Edition, Table 12.1. Columns B and D.

Conditions of Acceptability -

- 1. These devices should be used within Recognized ratings as specified above.
- These devices should be mounted in the intended manner in an enclosure having adequate strength and thickness and with acceptable spacings being provided.
- 3. The terminals of these devices have not been evaluated for field wiring and are for factory wiring only.
- 4. These devices are designed to trip within the curve characteristics provided by the manufacturer. (See ILL, 1 of this Report).
 - 5. These devices have a "trip free" construction.
- 6. Cat. No. 8340 devices have been tested for short circuit conditions without a series fuse.
- 7. Cat. No. 8340-F/G/T 50 A devices were subjected to 3000 c operations at rated current. This rating will represent an isolation switch rating. The 50 A devices were not subjected to the 6000 operations in UL 1077.