



Certificate of Compliance

Certificate Number: LR 12730-365
KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

Issued To: Siemens AG
Abt. ASI 2 GWA TPA
Werner von Siemens
Strasse 48
92220 AMBERG
Germany

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski
CSA Montreal

Signature

PRODUCTS

Contactors, open types, Series 3RT1034, 3RT1035, 3RT1036, with the following ratings:

Voltage	Horsepower 3RT1034	
	1-ph	3-ph
115 V	2 hp	--
200 V	5 hp	10 hp
230/240 V	5 hp	10 hp
460/480 V	--	25 hp
575 V	--	30 hp
600 V	--	30 hp



Certificate of Compliance

Certificate Number: LR 12730-365
KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

Voltage	Horsepower 3RT1035	
	1-ph	3-ph
115 V	3 hp	--
200 V	5 hp	10 hp
230/240 V	7 1/2 hp	15 hp
460/480 V	--	30 HP
575 V	--	40 HP
600 V	--	40 hp

Voltage	Horsepower 3RT1036	
	1-ph	3-ph
115 V	3 hp	--
200 V	7 1/2 hp	15 hp
230/240 V	7 1/2 hp	15 hp
460/480 V	--	40 hp
575 V	--	50 hp
600 V	--	50 hp

Main Contacts: General Purpose
- Type 3RT1044: 600 Vac 90 A
- Type 3RT1045 or 3RT1046: 600 Vac 105 A

Auxiliary Contacts: A600/Q600 240 V/10 A general purpose
Auxiliary contact blocks Type 3RH19 are top or side mounted

Coil Ratings: 24 through 600 Vac
24 through 250 Vdc

Notes:

- 1 The type designation may be completed with suffixes indicating contact arrangements, terminal design, mounting etc.
- 2 Certified as component for use only in Certified equipment where the acceptability of combination is to be determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements
" " " " 14 - 95 - Industrial Control Equipment