



Underwriters Laboratories Inc.®

1655 Scott Boulevard
Santa Clara, California 95050-4188
(408) 985-2400
FAX No. (408) 298-3266
MCI Mail No. 258-3283
Cable ULINC SANTA CLARA, CA
Telex No. (TRT) 184-219

**File E133211
Project 92SC04055**

July 10, 1992

REPORT

ON

**COMPONENT-POWER SUPPLY, INFORMATION TECHNOLOGY EQUIPMENT
INCLUDING ELECTRICAL BUSINESS EQUIPMENT**

**Astec America Inc.
Oceanside, California**

Copyright © 1992 Underwriters Laboratories Inc.

**Underwriters Laboratories Inc. authorizes the above named
company to reproduce this Report provided it is reproduced
in its entirety.**

**Underwriters Laboratories Inc. authorizes the above named
company to reproduce that portion of this Report consisting
of this Cover Page through Page 3.**

**A not-for-profit organization
dedicated to public safety and
committed to quality service**

D E S C R I P T I O N

PRODUCT COVERED

* Component - Switching Power Supply, Information Technology Equipment including Electrical Business Equipment, Model Series VS1-XY-XY and VS3-XY-XY-XY-XY, where X is A, B, C, D, E, F, G, H, K, or L and Y is one, two or three digits 0 through 9, each may be followed by additional suffix numbers. Number of -XY suffixes corresponds with the number of output modules supplied.

ELECTRICAL RATING:

Model Series	Input		Hz	Output dc	
	V	A		V	W
*VS1	115-230	15 A max.	50-60	2-48 V dc	1500 W max.

VS1 has up to two output modules, maximum 3 outputs each. Output voltages set at factory.

* Maximum 1500 W continuous output in a 50°C ambient. Maximum 900 W continuous output in a 70°C ambient evaluated with 112 cfm forced air cooling. Airflow is reversible, up to 40°C at 100% load.

Model Series	Output dc V	Input		V	W
		A	Hz		
VS3	115-230	15 A max.	50-60	2-48 V dc	1200 - 2000 W max.

VS3 has up to four output modules, maximum 3 outputs each. Output voltages set at factory and marked adjacent to each connector.

Maximum 2000 W continuous output in a 50°C ambient. Maximum 1200 W continuous output in a 70°C ambient evaluated with 156 cfm forced air cooling. Airflow is reversible, up to 40°C at 100% load.

Output Module Code

Output Voltage Code

A	equals 300 watt output module with Single Output. Maximum Output current 60 A.				
-X: B	equals 600 watt output module with single output Maximum output current 120 A.	Y:	0	=	2 V
			1	=	3.3 V
			2	=	5 V
C	equals 900 watt output module with single output. Maximum output 180 A.		3	=	12 V
			4	=	15 V
			5	=	24 V
D	equals 1200 watt output Module with single output Maximum output current 240 A		6	=	28 V
			7	=	36 V
E	equals 250 watt output module with two outputs. Main output rated max. 25 A Auxiliary outputs rated max. 10 A		8	=	2-48 VDC
			9	=	240-25 A 48 V
F	equals 250 watt output module with three outputs. Main output Rated Max. 25 A Auxiliary Outputs each rated Max. 5 A				
G	equals 500 watt output Module with two outputs Main output rated max. 50 A Auxiliary output rated max. 20 A				
H	equals 500 watt output Module with three outputs Main output rated max. 50 A Auxiliary outputs each rated max. 10 A.				

Output Module Code

Output Voltage Code

- K equals 750 watt output
Module with single output
Maximum output current 150 A
- L equals 1500 watt output
Module with single output
Maximum output current 300 A

ENGINEERING CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE USE):

This product was investigated under the Standard for Information Technology Equipment, UL 1950, First Edition, dated March 15, 1989.

Use - For use only in (or with) complete equipment where the acceptability of the combination is determined by Underwriters Laboratories Inc.

Conditions of Acceptability - When installed in the end-use equipment, consideration shall be given to the following:

1. This component has been judged on the basis of the required spacings in the Standard for Information Technology Equipment, Sub-Clause 2.9, which would cover the component itself if submitted for unrestricted Listing.
2. An acceptable enclosure shall be provided in the end-use.
3. The terminals and connectors have not been evaluated for field wiring.
4. These power supplies were evaluated for connection to a TN power system.
5. This power supply is considered a Class I product. The power supply shall be properly bonded to the main earthing termination in the end-use.
6. Bonding terminals provided on this equipment have not been evaluated as protective earthing terminals.
7. These power supplies have outputs that exceed 240 VA at a potential of 2 V or more.

8. This power supply has been evaluated for use in a 50°C ambient at full rated output, 70°C ambient at 60% rated output. A 112 cfm external reversible fan was utilized during testing of Model VS1, 156 cfm for Model VS3.
9. The outputs of these power supplies are considered SELV.
10. The Capacitance Discharge Test should be repeated in the end-use installation with the primary fuse (P1) opened or removed since the voltage across the power supply terminals was 340 V peak after 1 second
11. The Leakage Current Test should be repeated in the end use installation. A 3.6 mA leakage current was measured. Consideration should be given to marking the end-use product with "high leakage current-earth connection essential before connecting supply."