CERTIFICATE

Product Safety

Reference No./pos

0039099/01

Product

Relay

Certificate holder/ manufacturer TYCO ELECTRONICS AUSTRIA GMBH

Schrackstrasse 1

AT-3830 Waidhofen/Thaya

AUSTRIA

Type designation

V23...-A..

Technical data

Rated Voltage (V): 250 Class: II

Rated Current (A): 4/32 Pattern No: 1

Coil voltage: 5-60V DC.

The product complies with the standard(s)

SEMKO 124-1966 (CEE 24) and SEMKO 25

Date of expiry

31 December 2002

LVD Information

The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Terms and additional information overleaf and in Appendix 1.

Stockholm 17 October 2000 **SEMKO AB**

Product Certification

Pär Zetterberg





Additional Information and Manufacturing site

Manufacturing site:

LEXA Hamr-Kosky 57 CZ-37804 Chlum Trebone CZECH REPUBLIC

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

This certificate replaces previously issued ref. No. 9209089/01 dated 31 March 1992 for relays of type V23...-...-A... A new certificate has been issued on account of that the company name has been changed to Tyco Electronics Austria GmbH.

Replaces previously issued Appendix dated 17 October 2000. A new Appendix has been issued on account of change manufacturing site.