

## Product Certification Schedule

Schedule No: 017/003/217

Licensee: PRYSMIAN CABLES & SYSTEMS LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: PRYSMIAN CABLES & SYSTEMS LTD, HARRIET STREET, TRECYNON, ABERDARE, SOUTH WALES, CF44 0TD

Specification: BS 6004:2012 Electric Cables - PVC insulated and PVC sheathed cables for voltages up to and including 300/500V, for electric power and lighting

Type of Cable: Table 4 - PVC insulated, PVC sheathed cable with circuit protective conductor (CPC), 300/500 V, single core 6241Y, flat twin 6242Y and flat 3-core 6243Y

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1sqmm to 1.5sqmm nominal cross-sectional area of conductors inclusive. Single core & flat 3-core only. Class 1 conductor. 1sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive. Flat twin. Class 1 conductor. 4sqmm to 16sqmm nominal cross-sectional area of conductors inclusive. Flat twin. Class 2 conductor. Sheath - Type 6. Insulation - T11.

Origin Thread: Not applicable

Origin Mark: BRITCABLE (A) or PRYSMIAN (A)

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004