



Datasheet

RS PRO 5m Power Cable


Stock No: 146-9130



AMENDMENT RECORD


REF. No.	DESCRIPTION OF CHANGES	DATE
146-9130	(1) FIRST SUBMISSION.	11/09/17
(VPE09-042-17)		
ISSUE : 001		
146-9130	(1) CHANGE CUSTOMER P/N FM. 'VNUS15S3-NVC13S-5.ØM'	30/10/17
(VPE10-075-17)	TO '146913Ø(V-NOVUS US-C13 5M)' ON COVER &	
ISSUE : 002	ASSEMBLY DWG. PAGES.	
146-9130	(1) CHANGE CABLE MARKING FM. 'INK MARK' TO 'INDENTED'	29/11/17
(EVPE11-050-17)	& REMOVE ITEM No. '1810152' FM. ASSEMBLY DWG. PAGE.	
ISSUE : 003		
146-9130	(1) ADD IN PE BAG '904036' & LABEL 'VL-0538'	25/01/18
(VPE01-048-18)	AS SHOWN ON ASSEMBLY DWG. PAGE	
ISSUE: 004	(2) ADD IN NOTE 6 AS SHOWN ON ASSEMBLY DWG. PAGE.	
	(3) ADD IN LABEL DWG. PAGE.	
146-9130	(1) CHANGE LABEL FM. 'VL-0538' TO 'L-T383' & REMOVE	14/02/18
(EVPE02-120-18)	NOTE 6 FROM ASSEMBLY DWG. PAGE.	
ISSUE: 005	(2) CHANGE LABEL DWG. PAGE.	





Date :

Date :



APPROVED SOURCE FOR CABLE

1. BAO HING(SHENZHEN).(VOLEX-ULBH-054-W)

NOTE:


- 1. ALL DIMENSIONS IN mm.
- 2. THE CORD SHALL COMPLY WITH NMX-J-436-ANCE + CSA C22.2 NO.49 + UL 62.
- 3. THE MOLDED PLUG SHALL COMPLY WITH UL498, UL817, CSA C22.2 NO.21-95.
- 4. THE MOLDED CONNECTOR SHALL COMPLY WITH UL817, CSA C22.2 NO.21-95 AND C22.2 NO. 182.3-M1987.
- 5. THIS PART CAN BE MANUFACTURED AT ANY LOCATION WHICH HAS SAFETY APPROVAL.

6	RS LABEL 45X25MM L-T383				1		
5	BAG PE 356X508X0.05 904036				1		
4	8" PE TIE (3LK			6310062		1
	IP40G NL792B BLK 4100017				_		
3	MOLDED CON	NECTOR V	NC13S (10	A 125V)	VNC13S-V		1
	IP40G NL792B BLK 4100017					_	
2	MOLDED PLUG VNUS15S3 (10A 125V) VNUS15S3-V 1		1				
1	SVT 18/3 105°C BWG BLK PVC LEAD FREE(INDENTED)				1		
S/N	DESCRIPTION ITEM NUMB			ER	QTY		
TITLE :	TITLE : NORTH-AMERICAN POWER SUPPLY CORDSET (PB FR) SCALE : N.T.S.						
CUSTOME	CUSTOMER : PAGE : 1/1						
CUSTOME	CUSTOMER PART NUMBER: 146913Ø(V-NOVUS US-C13 5M) ISSUE						
Reference Number: 146-9130					005		
SALES :	QA :	ENGRG:	CHECKED BY:	DRAWN BY :	1	•	

Date :

23/02/18

19/02/18 14/02/18



REV.	DESCRIPTION	DATE
Ε	ADD IN INSULATION COLOR 'BWGY'.	11/09/06
	CHANGE COMPLIANCE STANDARD & UPDATE	
F	VALUES PER PRODUCT SAFETY.	05/07/07

1. PVC FLEXIBLE CORD

1.1 SCOPE

⚠ This specification shall be in accordance with NMX-J-436-ANCE + CSA C22.2 N0.49 + UL 62.

1.2 CONSTRUCTION

CONDUCTOR	ANNEALED COPPER WIRE
INSULATION	PVC (BLACK, WHITE & GREEN) OR (BLUE, BROWN, GREEN& YELLOW) OR (BLACK, WHITE, GREEN&YELLOW)
JACKET	PVC

	ITEM	UNIT	SPEC. VALUE
Ì	TEMPERATIRE RATING	.c	105
	MAXIMUM VOLTAGE	٧	300
	NO. OF CONDUCTORS	NO.	3
Æ	SIZE OF CONDUCTORS	mm² (AWG)	0.824 (18)
Æ	CONDUCTOR DIAMETER OF INDIVIDUAL WIRES	mm (in)	0.125-0.165(0.0049-0.0065)
Æ	MIN. AVE. THICKNESS OF INSULATION	mm (mils)	0.38 (15)
Æ	MIN. THICKNESS AT ANY POINT OF INSULATION	mm (mils)	0.34 (13.5)
Æ	MIN. AVE. THICKNESS OF JACKET	mm (mils)	0.76 (30)
Æ	MIN. THICKNESS AT ANY POINT OF JACKET	mm (mils)	0.61 (24)
Æ	OVERALL DIAMETER OF JACKET	mm (in)	5.84-6.73 (0.230-0.265)
	DIELECTRIC-STRENGTH TEST- IN THE AIR 20±5°C	_	1500V for 1 min.
	SPARK TEST	V/sec	3000/0.18 (For 50 Hz) 3000/0.15 (For 60 Hz)
Æ	INSULATION RESISTANCE AT 15°C	-	>=0.76Gohm (2.5 Mohm 1000 ft)

TITLE: CABLE SPECIFICATION

UL/CSA APPROVED POWER SUPPLY CABLE

SVT 18/3 105°C

SPEC NO. :

CS-015UL





REV.	DESCRIPTION	DATE
	ADD IN NEW CABLE MARKING.	
8	ADD IN 'UL/CSA' ON THE TITLE.	04/07/07
С	REMOVE OLD MARKING AS SHOWN.	27/11/08

CABLE MARKING

BAO HING (SHENZHEN)

 \triangle

:- (UL) SVT E159216 VW-1 300V 105°C 3X18AWG BAOHING CSA SVT LL112007 VW-1 300V 105°C 3X0.824mm²(18AWG) LF

DRAWN	HONGYAN	27/11/08	FILE NAME :	TITLE : CABLE MARKING
CHECK		フリリリのと	BAO HING/SVT/	WELL CADES MARKING
APPR	Marca	28/11/08	SVT 18X3 105 -LF-BH(SZ)	(UL/CSA)
SCALE	N.T.S.	REV.	С	, , , ,

REFERENCE :

SVT 18/3 105°C LF





2. PLUG

REV	DESCRIPTION	DATE
BF	ADD IN CATALOGUE NO. CSUS15S3.	07/09/16
BG	ADD IN CATALOGUE NO. DGUSJ515HS3.	29/03/17

2.1. SCOPE

The specification applies to plug in compliance with UL498, UL817 and CSA C22.2 No.21-95. Except for the plug molded with SJT-R or SVT-R cable shall be in according to UL498 & UL817.

2.2. CONSTRUCTION

The plug construction shall comply with our catalogue No: ME301,ME301R,ME301P, ME301RP,ME301S,ME302,ME302P,ME302GR,ME302GRP,PS204,PS204A,PS204D, PS204GR,PS206,MP204,VS205A,VS205S,VS207A,VS208A,US15B,US15BP,US115PSC, US115SC,US115LS,US115LPS,USJ15B,US115S,USI515A,US515SC,PS520,PS620, PS206A,926,926SR,US650A, US515A, US115VPS2, US15S3, US15S2, MA115VPS2, 926BSR, 926NPSR, US515BTA3, 953, USJ15TS3, US15GPS2, US115DPS2, VPUS15S3, PL-3001,VPUS15DS3, PS520A, CX-394S, VPUS15S2, USD15GPS2, USD115PS2, APUS15S3, DS15PS2, APUS15S2, DS15FPS2, DS15EPS2, DS15JPS2, US520A3 DS15FBPS2, MFUS15S2, HO515S3,DLUS15S3, VNUS15S2, LSUS15THA3, USL515PS3, VNUS15S3, VNUS15S3, VNUS15S3, VNUS15S3, VNUS15FBS3.

2.3. CHARACTERISTICS

NO. TEST ITEM		DECCRIPTION	ACCEPTANCE
NO.	1ESI IIEWI	DESCRIPTION	CRITERIA
1.	Conductor	A force of 20lbf (89N) is applied on the connection	The connection
	secureness test	between the blade and conductor for 1 min.	shall not break.
2.	Strain relief	A pull of 30lbf (133N) is applied between the	There shall not be any damage
	test	cord and fitting for 1 min.	to the cord and fitting.
	(May be exempted with		For hospital grade plug, the
	abrupt pull test)		cord shall not been
			displaced by more
			than 0.8mm.
3.	Insulation resistance	A D.C 500V is applied to the following;	
	test	i) between live parts of opposite polarity for	
		Class I & Class II plugs.	
		ii) between live parts and grounded parts for	Min. 100 M Ohm
		Class I plug only.	
		iii) between live parts and exposed surfaces for	
		Class I & Class II plugs.	
4.	Temperature rise	A rated current is passed through the cord for	The rise in temperature
	test	4 hours.	of the blades shall not
			exceed 30°C.
5.	Dielectric voltage	An alternating voltage of 1250V is applied	There shall be no arching,
	withstand test	between each conductors for 1 min.	breakdown or flashover
6.	Accelerated aging	The sample is placed in an oven at a temperature	There shall be
	test	of 100±1°C for 96 hours.	no damage.
7	Crushing test	After ageing for 7 days at 90±1°C, a pressure of	The shall be no damage
		75lbf (334N) (500lbf for hospital grade) shall be	and expose of live parts.
		applied on the fitting for 1 min.	

DRAWN:	WANGHUI	29/03/17	TITLE:
CHECK:	hongyan	29/03/17	NORTH-AMERICAN
APPR:	hoith	29/03/17	PLUG
REV:	BG		
REFERENCE:	:		_
			S PA





NO.	TEST ITEM	DESCRIPTION	ACCEPTANCE CRITERIA
8	Flexing test (applicable only to parallel cord)	The sample is secured on an oscillating member with a weight of 284g(HPN cord) or 113g(others) and moved backward and forward through an angle of 180° (90° on each vertical side) for 2500 cycles. Rate of cycle is 10/min. and each cycle is from the left to the right and back again.	The conductors on each core shall not have been completely broken.
9	Abrupt pull test	i) Cords with grounding conductor. The plug is inserted into a receptacle with grounding pin on the up position. The angle is 45°. The blades are secured with set screws. A weight of 2.5lb (1.1Kg) is impacted by pulling on the cord for 25 times dropped at height of 10 inches (254mm). A current of 40A at 6-12V is then applied to the grounding conductor for 2 mins. ii) Cords with two conductors. Similar to item (i) but with only 5 impacts and the height is 7 inches (178mm).	No open circuit of any conductors.
10	Abrupt removal test (Hospital grade only)	The preparation is similar to item (9i) but the angle is at 90° and the blades are not secured. A 10lb (4.5Kg) weight is dropped from a height of 24 inches (610mm).	The plug shall be completely removed from the receptacle.
11	Jacket retention test	 i) Similar to item (9i) but with only 10 impacts. ii) Similar to item (12) but the 15lbf(67N) is applied at 8 inches from the cord entrance. A weight of 3 lb(1.33kg) is then suspended 8 inches from the cord entrance for 15s. It is then rotated 360° in 15s. 	No fillers, separators, insulation or bare conductors shall be seen on the cord entrance area.
12	Security of insulation test (Applicable to parallel cord only)	Insulation on each conductor is slitted open at approx. 25mm from it's entry. All strands of conductor are to be severed. A pull of 15lbf (67N) is applied for 2 min between all blades and free end of the cord.	There shall not be any detachment of insulation from the plug or baring of conductors.
13	Blade pull test at elevated temp.	The sample is conditioned at 60°C. A 10lbf (44.5N) pull is applied to the blades in succession for 4 hours at 60°C. The weight is then removed and the sample is allowed to cool to room temperature.	The blades must not been displaced by more than 1.6mm.
14	Security of blades test	A force of 20lbf (89N) is applied for 2 min. at each blade in succession.	After the removal of the weight, the blades shall not be displaced by more than 2.4mm.

REV:	BG		
APPR:	heith	29/03/17	PLUG
CHECK:	hongyan	29/03/17	NORTH-AMERICAN
DRAWN:	WANGHUI	29/03/17	TITLE:





NO.	TEST ITEM	DESCRIPTION	ACCEPTANCE CRITERIA
15	Impact Resistance Test	After ageing for 7 days at 90±1°C, the fitting is allowed to cool to room temperature. The fitting with a cable length of about 45 in (1143 mm) is to be mounedt on a vertical wall with the plug hanging freely along a striking block. The plug is lifted vertically up but about 36 in (965 mm) away from the wall. The plug is than let go and be allowed to strike the block. This is to be repeated 1000 times.	There shall be no damage to the fitting.
16	Rotary Pull (applicable only to hospital grade)	The plug is moulded with the flexible cord without the conductors terminated to the blades or grounding pin. The cord is than subjected to a vertical force of 10lbf (44.5N) and rotated at a rated of 9rpm in a 3 in diameter circle at a point 6 in (152mm) below the cord exit for 2 hours.	The conductors shall not have been displaced by more than 0.8mm.
17	Adhesion test (applicable only to outdoor-use)	Adhesion between the cord and the body of the fitting shall be determined by bending the cord to an angle of 90° with the plane of the cord entry.	The area shall be examined visually for openings that would likely permit the entry of moisture into the body. If the visual examination cannot verify that acceptable adhesion exists, the plug may be cut apart for examination. The adhesion may be determined to be acceptable if the examination of the inner construction reveals a positive seal at all points around the periphery of the cord.
18	Weather (sunlight) resistance test (applicable only to outdoor-use)	If the plastic material is not tested for weather resistance, then the plugs/connectors/assemblies shall be subjected to conditioning according to CSA C22.2 No. 2556 or CSA C22.2 0.17 for 720 hrs (carbon arc) or 1000 hrs (Xenon-arc), and then subjected to crushing and impact resistance test.	After crushing test, there shall be no damage and expose of live parts. After impact resistance test, there shall be no damage to the fitting.

DRAWN:	WANGHUI	29/03/17	TITLE:
CHECK:	hongyan	29/03/17	NORTH-AMERICAN
APPR:	heith	29/03/17	PLUG
REV:	BG		
REFERENCE	Ξ:		
			-
			4º PRO





3. CONNECTOR

REV	DESCRIPTION				
BB	ADD IN CATALOGUE NO.DGC13S, DGC13A & DGC19S.	29/03/17			
BC	ADD IN CATALOGUE NO. VAC5AL.	20/06/17			

3.1. SCOPE

The specification applies to connector in compliance with UL817, CSA C22.2 No. 21-95 and C22.2 No. 182.3-M1987.

The connector shall generally complies to IEC 60320-1 with the exception of catalogue no. PS309/P & MS212A.

3.2. CONSTRUCTION

The connector construction shall comply with our catalogue No: VAC5S, VAC5AR, 25AC5, APC5A, APC5M, APC5S, APC5SM, APC5SP, APC7S, APC7Q, APC7M, VAC7S, SZC7S, APC13, APC13S, VSCC13, AVLC13, VAC7A, VAC7PS, VIC13A, M1625, V1625,V1625LA, V1625A, V1625BA, V1625BS, VAC15S, VAC15BS, VAC17S, VAC17BS, PIC17BS, PIC17S, VAC19, VAC19A, VSC19, DLC5A3, DLC5SA3, PS625, PS625A, MS225, PS309, PS309P, MS212, MS212A, APC13F, APC13G, DLC7U2, AP7M16, 386A, VAC17A, VAC13KS, DLC5U3, VCC13, VAC19KS, DLC7E2, DLC5E3, HPC13A,V1625AT, CN-4001, SOC7S, APC5SF, VCC5S, VCC7S, APC7H, APC13H, V1625H, VAC19H, APC7K, APC13FH, APC13HC, MFC7S, VAC15A, 386AL, VAC17KS, APC7HB, VAC13CS, VAC13AD, VAC13AU, DLC5CS3, VNC7S, VNC13S, VNC5S, VNC13A, VNC7A, VNC5FS, DGC13S, DGC13A, DGC19S & VAC5AL.

3.3. CHARACTERISTICS

NO. TEST ITEM		DESCRIPTION	ACCEPTANCE
110.	TEST TIEN	DESCRITION	CRITERIA
1.	Conductor	A force of 20lbf (89N) is applied on the con-	The connection
	secureness	nection between the contact and conductor for	shall not break.
	test	1 min.	
2.	Strain relief	A pull of 30lbf (133N) is applied between the	There shall not be any
	test	cord and fitting for 1 min.	damage to the cord
			and fitting.
3.	Insulation resistance	A D.C 500V is applied between conductors and	Min. 100 M Ohm
	test	between current carrying parts and body.	
4.	Temperature rise	A rated current is passed through the cord for	The rise in temperature
	test	4 hours.	of the contacts shall not
			exceed 30°C.
5.	Dielectric voltage	An alternating voltage of 1250V is applied	There shall be no arching
	withstand test	between each conductors for 1 min.	breakdown or flashover
6.	Accelerated aging	The sample is placed in an oven at a temperature	There shall be
	test	of 100±1°C for 96 hours.	no damage.
7.	Flexing test	The sample is secured on an oscillating member	The conductors on
	(applicable only to	with a weight of 284g(HPN cord) or 113g(others)	each core shall not
	parallel cord)	and moved backward and forward through an	have been completely
		angle of 180° (90° on each vertical side) for 2500	broken.
		cycles. Rate of cycle is 10/min. and each cycle is	
		from the left to the right and back again.	

DRAWN:	JIN JU	20/06/17	TITLE:
CHECK:	Feng	20/06/17	NORTH-AMERICAN
APPR:	heith	20/06/17	CONNECTOR
REV:	BC		
REFERENCE:			








NO.	TEST ITEM	DESCRIPTION	ACCEPTANCE CRITERIA
8.	Jacket retention test	Insulation on each conductor is slitted open at approx. 25mm from cord entry. All strands of conductor are to be severed. A pull of 15lbf (67N) is applied for 2 min. between fitting and free end of cord.	There shall not be any detachment of insulation from the connector.


DRAWN:	JIN JU	20/06/17	TITLE:
СНЕСК:	Feng	20/06/17	NORTH-AMERICAN
APPR:	heith	20/06/17	CONNECTOR
REV:	BC		
REFERENCE:			QS PR














LILY ZHOU



TABLE:

CURRENT (XXA)

NOTES:

- 1) ALL DIMENSIONS IN mm.
- 2) X CAVITY NO. (OPTIONAL)
- 3) XXX MANUFACTURING LOCATION.
- 4) XXA 125V \sim RATING. (REFER TO TABLE)
- 5) VENDOR'S TRADEMARK MUST BE ON THE BLADE.
- 6) YEAR & MONTH & WEEK CODE INSERT :



YEAR X X 2015 = 1 5 2016 = 1 6



 $1 \sim 5$ — week of the month

10A

2.5A

A

SM	HENG GANG (CHINA)	х	DRAW		
SM1/SMI	ZHONGSHAN (CHINA)	x	CHECK		
3M 1/ 3M1		Ĥ	APPR		
VH	HANOI (VIETNAM)	Х	REV.		
В	BATAM (INDONESIA)	×	REFE		
vc	CHENNAI (INDIA)	x			
MANUFACTURE LOCATION MARK					

MANUFACTURE LOCATION MARK
(' X ' IS APPLICABLE ONLY)

MOLDED PLUG

Light Plug/Ulacsa

MOLDED PLUG

Light Plug/Ulacsa

VNUS15S3

B SCALE N.T.S.


ERENCE:


TITLE :


23/09/15 FILE NAME :

NORTH-AMERICAN APPROVAL


REV.	DESCRIPTION	DATE
Α	initial release.	22/04/15
В	ADD IN RATING '12A & 13A & 250V' AS SHOWN.	27/06/15
















Ξ						
	CURRENT (XXA)	10A	\	12A	13A	
	VOLTAGE (XXXV~)	125V~	\	250V~		





NOTES :

- 1.) ALL DIMENSIONS IN mm.
- 2.) X CAVITY NO. (OPTIONAL)
- 3.) XXA XXXV~ RATING. (REFER TO TABLE)
- 4.) XXX MANUFACTURING LOCATION.

SM	HENG GANG (CHINA)	x	DRAWN	TIAN SHUO	27/06/15	FILE NAME :	TITLE:		
SM1/SMI	ZHONGSHAN (CHINA)	x	CHECK	110-3000	21/06/15	A-CONNECTOR/ ULACSA/GENERAL	MOLDED CONNECTOR		
	LIANOL CALIBRAN		APPR	reng	27/6/15	/VNC13SULCSA	VNC13S		
VH	HANOI (VIETNAM)	X	REV.	В	SCALE	N.T.S.			
В	BATAM (INDONESIA)	X	REFER	ENCE :					
VC	CHENNAI (INDIA)	x	MODI	NORTH-AMERICAN APPROVAL					
	ACTURE LOCATION MARK ' IS APPLICABLE ONLY)	NUK	тн-амк	RICAN A	PPROVAL				