





Kitemark™ Certificate

This is to certify that: Fireblitz Extinguisher Ltd

15 & 17 Manford Industrial Estate

Manor Road

Erith DA8 2AJ

United Kingdom

Holds Certificate Number: KM 551491

In respect of:

BS EN 3 Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

Shahm Barhom, Group Product Certification Director

First Issued: 2009-10-12 Effective Date: 2022-09-14 Latest Issue: 2022-09-14 Expiry Date: 2026-03-08

Page: 1 of 2



For and on behalf of BSI:



Kitemark™ Certificate

No. KM 551491

Model Number	Description
FBP1	1 kg ABC powder, stored pressure. Fire rating 5A & 34B
FBP2	2 kg ABC powder, stored pressure. Fire rating 13A & 70B
FBP6	6 kg ABC powder, stored pressure. Fire rating 27A & 144B
FBP9	9 kg ABC powder, stored pressure. Fire rating 34A & 233B
FBF6	6 litre foam, stored pressure. Fire rating 13A & 144B
FBF9	9 litre foam, stored pressure. Fire rating 21A & 183B
FBW9	9 litre water, stored pressure. Fire rating 13A
FBC2	2 kg carbon dioxide. Fire rating 34B
FBC5	5 kg carbon dioxide. Fire rating 70B

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2009-10-12 Effective Date: 2022-09-14 Latest Issue: 2022-09-14 Expiry Date: 2026-03-08

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.