

For the attention of the Managing Director

Dear Sir / Madam,

Product Notice
Rockwell - Customer Notification

This notification relates to the Rockwell LifeLine 4 rope pull safety switch detailed below, supplied by RS Components Ltd between 25th **January 2010** and 20th **June 2010**.

Article	Article description	MPN (market)
2451501	Hazardous area grab wire switch,1NC 1NO	440E-H13046
2263180	Rope & push button emergency stop switch	440E-L13042

Our records show that you have purchased 1 or more of these products.

Note that there are other models listed on the Rockwell notification but these have not been supplied by RS Components Ltd.

Rockwell have informed us that some Lifeline 4 Cable Pull Switches will not activate as intended. The tolerance of some assembly elements are such that the switch may not trip as a result of a 'pulled' cable.

Please refer to the enclosed communication from Rockwell for further information on identifying and testing affected switches.

If you find that you have one of the affected switches please do not contact RS Components.

Rockwell have asked us to direct you to contact their UK Technical Support Team on 01908 635245 for technical advice and replacements.

Please accept our apologies in advance for any inconvenience caused.

RS Components Limited