

Certificate of Compliance

Certificate: 1167056

Master Contract: 164581 (LR 58905)

Project: 1167056


Date Issued: February 19, 2001

Issued to: **TELEMECANIQUE/SCHNEIDER ELECTRIC
INDUSTRIES S.A.**
33 bis, Avenue du Marechal Joffre
F-92002 Nanterre Cedex
FRANCE


The products listed below are eligible to bear the CSA Mark shown



Issued by:


J-P Boivin, Eng.

Authorized by:


Alain Ste-Marie
Operations Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I Division 2 Groups A, B, C and D, temperature Code T3C-160°C.

The following are in compliance with Std C22.2 No. 213-M1987. Programmable controllers, Series Micro, Serie TSX37-05, TSX37-10, TSX37-21, TSX37-22 and TSX37-08 followed by suffixes; Input and output modules, extension modules and accessories, models TSX-RKZ2, -RKA01, -DMZ, -DEZ, -DSZ, -AEZ, -ASZ, -CTZ; -MRP032, -MFP032, -MFPBAK032, -CDP, -CAPH, -CAPS, -SCPCC, -SCPCC, SCPCD, SCPCM, SCPCU, SCPCX; TSX-SCP11, TSX-STZ10, TSX-DPZ10D2A Emergency stop security module, TSX-SAZ10, each designations may be followed by suffixes.

Reference TSX37-10.. supply 100 to 240V ac - 16VA, 24V dc, 8.1W.

Reference TSX37-21.., TSX37-22.. supply 100 to 240V ac, 24VA, 24V dc, 16W.

Reference TSX37-05, TSX37-10.. supply 100 to 240V ac - 16VA, 24V dc, 8.1W.

Reference TSX37-08, TSX37-21.., TSX37-22.. supply 100 to 240V ac, 24VA, 24V dc, 16W.

APPLICABLE REQUIREMENTS

- | | | |
|-----------------------------|---|---|
| CAN/CSA-C22.2 No. 14-95 | - | Industrial Control Equipment |
| CSA Std C22.2 No. 142-M1987 | - | Process Control Equipment |
| CSA Std C22.2 No. 213-M1987 | - | Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations |



Certificate of Compliance

USINE

Certificate Number: LR 58905-30

Revision: LR 58905-45

Date Issued: May 7, 1999

Issued To: **TELEMECANIQUE / SCHNEIDER ELECTRIC S.A.**
33 bis, Avenue du Maréchal Joffre
92002 Nanterre
Cédex, France

The products listed below are eligible to bear the CSA Mark shown



Issued by: J. -P. Boivin, Eng.

Signature: _____

PRODUCTS

CLASS 2252 01 - PROCESS CONTROL EQUIPMENT

Programmable controllers, Serie TSX37-05, TSX37-10, TSX37-21, TSX37-22 and TSX37-08 followed by suffixes; Input and output modules, extension modules and accessories, models TSX-RKZ2, -RKA01, -DMZ, -DEZ, -DSZ, -AEZ, -ASZ, -CFZ, -CTZ; TSX-CAZ11, -MRP032, -MFP032, -MFPBAK032, -CDP, -CAPH, -CAPS, -SCPCC, -SCPCC, SCPCD, SCPCM, SCPCU, SCPCX; TSX-SCP11, TSX-STZ10, TSX-DPZ10D2A Emergency stop security module, TSX-SAZ10, each designations may be followed by suffixes.

APPLICABLE STANDARDS

CSA Std C22.2 No. 142-M1987 - Process Control Equipment



Certificate No: LR 58905-30

Date: May 7, 1999

Revision: LR 58905-45

Product Certification History

Revision	Date	Description
LR 58905-45	May 7/ 1999	Addition of product reference TSX37-05 and -08.
LR 58905-40	March 17, 1998	Addition of module TSX-DPZ10D2A and TSX-SAZ10.
LR 58905-36	February 9, 1998	Addition of modules TSX-DEZ32.., TSX-DSZ32.. And TSX-DEZ08A5, 32 output max, 0.5A max.