



LR Type Approval Certificate Extension

This is to certify

that Certificate No. 93/00075 for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	Critchley Ltd
PLACE OF PRODUCTION	Wellington House Bath Road Woodchester Gloucestershire, GL5 5EY England
DESCRIPTION	Plain, closed slot and open slot Betaduct products, available in various colours of FVC.
TYPE	Order code specifications as outlined in Publication Reference 2175.
APPLICATION	Marine, offshore and industrial applications.
DESIGN CODE	Manufacturer's specification. Betaduct cable trunking.
RATING	Ambient temperature range -15°C to +60°C Surface spread of flame BS 476 Part 7 Class 1

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify LR of any modification or changes to the equipment in order to obtain a valid certificate."

All other details remain as the original Certificate No. 93/00075 to which this extension should be attached.

Certificate No.	93/00075(E1)
Issue Date	16 September 1998
Expiry Date	26 May 2003
Sheet	1 of 1

J.W. Prior



Lloyd's Register of Shipping
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register

Notice: This Extension to the LR Type Approval Certificate is subject to the terms and conditions

DESIGN APPRAISAL DOCUMENTDate
3 June 1999Quote this reference on all future communications
TAD/40764/99/JWP/O-14397**LLOYD'S REGISTER'S TYPE APPROVAL SYSTEM, 1996.**Issued to: **CRITCHLEY LIMITED****for: PLAIN, CLOSED SLOT AND OPEN SLOT BETADUCT PRODUCTS
TYPE APPROVAL CERTIFICATE No. 93/00075(E1)**

The undernoted documents have been reviewed for compliance with the requirements of Lloyd's Register's Type Approval System, 1996 and this Design Appraisal Document is a supplement to the Certificate.

APPROVAL DOCUMENTATION

Request form	16.06.1998
List of Drawing Numbers for Bases and Lids	14.01.1997
List of New Drawing Numbers for Bases & Lids	17.06.1998
Product data sheet 2245	1997
Product data sheet 2262	1997
Product data sheet 2263	1997
Product data sheet 2264	1997
Product data sheet 2265	1997
Product data sheet 2267	1997
LR Certificate No. BRS 9801395/1	20.08.1998
Critchley Fax	10.11.1998
Drawing Register	08.02.1999
Drawings of Betaduct Bases shown on register	6.5.98 to 29.10.98

TEST REPORTS

Those listed in document 93/00075 issue 2 30.01.1997



J.W. Prior
Type Approval Department, Extn. 4768

MM

Part 1
Subject: Electrical Equipment (Not Environmentally Tested)
Product: Cables and Accessories

Producer/Licence No.	Description of Product				Cert. No.
	Type	Details of Approval	Application	Remarks	
Crishley Limited, Willington House, Bath Road, Woodchester, Gloucestershire, GL4 5BY, England.	Bitduct	Flame, closed slot and open slot PVC, available in various colours.	Marine, offshore and industrial applications.	Expires: 26 May 2003 Complies with BS 476 Part 7 Class 1 Surface spread of flame. See Publication Z175 for sizes, order codes and materials.	93/01075(E1)

[Handwritten signature]
 16/2/98