

**TYPE APPROVAL CERTIFICATE**  
**N. ELE024212CS/001**

This is to certify that the product below is found to be in compliance with the applicable requirements of the RINA type approval system.

<i>Description</i>	<b>ELECTRICAL RELAYS</b>
<i>Type</i>	<b>Series 56</b>
<i>Applicant</i>	<b>FINDER S.p.A Via Drubiaglio 14 10040 Almese (TO) ITALY</b>
<i>Manufacturer</i>	<b>FINDER S.p.A Via Drubiaglio 14 10040 Almese (TO) ITALY</b>
<i>Testing Standards</i>	<b>EN 61810-1: 2008</b>

Issued in Genova on April 12, 2012

This certificate is valid until April 11, 2017

RINA

*Valerio Bonanni*


Genova, April 12, 2012

1/2



**TYPE APPROVAL CERTIFICATE**  
**N. ELE024212CS/001**

**Series 56 relay**



**Miniature relays Series 56.X(3;4) X(2;4) .X(8;9).XXX.XXXX**

Rated values	250 Vac 12 A ; 250 Vac 8,4 A (cosφ=0.4) ; 230/400 Vac 10 A
Ambient temperature	-40 +70 °C
Type of operation	Continuous
Electrical operating cycles	100.000 or 50.000 (according to contact materials)
Coil Insulation class	F
Coil rated voltage	8 - From 6 through 250 Vac - 1,5 VA (2 poles)
	8 - From 6 through 400 Vac - 2 VA (4 poles)
	9 - From 6 through 125 Vdc - 1 W (2 poles) 1.3 W (4 poles)

**Test reports**

IMQ n. E9971 (05/07/1992) updated on 22 /03/ 2012.

IMQ n. E9972 (05/07/1992) updated on 07 /02/ 2011.

IMQ n. 02LJ00043 (30/11/2009)

IMQ n. 02LJ00043/1 (30/11/2009)

**Technical documents**

FINDER data sheet 56 Series - Miniature power relays 12A

**Remarks**

Electrical relay to be used according to the manufacturer instruction.

Genova, April 12, 2012

2/2