



Certificate of Compliance

Certificate Number: LR 702770

Revision: LR 702770

Date Issued: August 31, 1998

Issued to: **Wieland Electric GMBH**
Brennerstrasse 10-14
D-96052 Bamberg/Bayern
Germany

The products listed below are eligible to bear the CSA Mark

Issued by: **Bal Johal,**
Engineering Group Assistant
Vancouver, BC Canada

Signature: 

PRODUCTS

EQUIPMENT CERTIFIED TO CSA STD C22.2 NO. 14-M1987 AND ECN NO 575B:

	Model No.	Input Rating	Output Loads
P o w e r I n t e r f a c e M o d u l e s	FLARE-24VDC-1W-250V 6A	24 V dc	240 V ac, B300, Pilot duty or 6 A resistive
	FLARE-24V-1S-250V 6A		24 V dc, R300, Pilot Duty or 6 A resistive
	FLARE-24VDC-1W-250V 6A-F	24 V ac/dc	240V ac, B300, Pilot duty or 6 A resistive 24 Vdc, R300, Pilot Duty or 6 A resistive
	FLARE-24V-1S-250V 6A-F		
	Screw terminals:		
	FLARE-24VDC-1W-250V 6A		
	Quick terminals:		
	FLARE-24VDC-1W-250V 6A-F		
	FLARE-24V-1W-48V 20M		
	FLARE-24V-1W-48V 20M-F		
FLARE-24V-1S-250V 6A-HA			
FLARE-24V-1W-250V 6A-CUT			
Quick terminals:			
FLARE-24V-1S-250V 6A-HA			
FLARE-24V-1W-250V 6A-CUT			



Certificate No: LR 702770

Date: August 31, 1998

Revision: LR 702770

Quick terminals:

FLARE-110V-1W-250V 6A-F

FLARE-110V-1W-250V 6A-F

Quick terminals:

FLARE-230V-1W-250V 6A-F

FLARE-230V-1W-250V 6A-F

110 V dc

240 V ac, B300, Pilot duty or 6 A resistive

24 V dc, R300, Pilot Duty or 6 A resistive

230 V ac/dc

Ambient Temperature 60°C

Devices are DIN rail mountable.