



## Product Registration Certificate

Printed on: 01 May 2014

<b>Registration No.</b>	<b>2492</b>
<b>Title</b>	<b>OT Switch Disconnecter</b>
<b>Status</b>	<b>Authorised For Use</b>
<b>Supersedes ProductID</b>	N/A
<b>Superseded By ProductID</b>	N/A
<b>Date Authorised for Use</b>	<b>24 Apr 2014</b>
<b>Primary Use</b>	Disconnection and Isolation of low voltage loads
<b>Additional Info/KeyWords</b>	3&4 pole 16 to 3150amp at 690v and 6&8 pole available upto 125amps, 690v. Full range of accessories available - manufactured to IEC-60947-1 & 3 Manufacturer: ABB Limited, Tower Court, Foleshill Enterprise Park, Courtaulds Way, Coventry. CV6 5NX. T:024 7636 8500
<b>Classification Hierarchy</b>	Electrical Stn Lighting & Pwr AC Only LUL Supplied-Local Distrbtn   LUL Supplied-Local Distrbtn
<b>Manufactured By</b>	ABB Ltd

### Requirements

ReqID	Requirement	Status	Trial
No records to display.			

### Conditions

Description	Linked To ReqID
These products are compliant for installations in surface locations and within one hour fire rated room of volume less than 75m <sup>3</sup> with a fire detection and alarm system in sub-surface locations, as specified in LU standard 1-085.	

### Evidence

EvidenceText	EvidenceType	FileName	Linked To ReqID
Product Catalogue	User Guide	OT and OTM New Cat(2492).pdf	

Reminder: Products must not be publicised as being authorised for use by London Underground Limited (LUL) without also stating any conditions or limitations that apply, nor may any LUL intellectual property rights (such as the roundel trademark) be used in any such publicity. LUL reserves the right to withdraw authorisation of any product publicised in breach of this reminder. Refer to Web site [www.lu-apr.co.uk](http://www.lu-apr.co.uk) to check current status, download attachments and for details of other products.

MAYOR OF LONDON