



## DECLARATION OF CONFORMITY

We **Novar ED&S Ltd (MK Electric)**  
of **The Arnold Centre, Paycocke Road, Basildon, Essex. UK. SS14 3EA**

Declare under our sole responsibility that the following products:

Sentry residual current operated circuit breakers with integral overcurrent protection (RCBO), SP with solid neutral, 1 module, Type AC, 230Va.c., 30mA trip

List No.

Rating	B-Type	C-Type
6A	7932s	8932s
10A	7933s	8933s
16A	7934s	8934s
20A	7935s	8935s
32A	7936s	8936s
40A	7937s	8937s
45A	7938s	8938s
50A	7939s	8950s

To which this declaration relates, are in conformity with the test requirements of the following standards:

IEC 61009-1:1996+A1, BS EN 61009-1:2004

Specification for residual current operated circuit breakers with integral overcurrent protection  
for household and similar uses (RCBO's)

and on the basis of this testing, these products are considered to comply with the essential requirements of the following EU Directives:

Low Voltage Directive (2006/95/EC), EMC Directive (2004/108/EC).

CE mark affixed – June 2009 (B-type 6-32A ratings), April 2010 (B-type 40-50A ratings), January 2012 (all C-type ratings)

Support Documentation reference: 907644, CB58133, DY11-I156

**Signature:**

A handwritten signature in black ink that reads 'K. Davis'.

**Print Name:**

K.Davis

**Function:**

Global Current Products Manager

Novar ED&S Limited operates a Quality Management System which is certified to **ISO9001** by a **UKAS** accredited certification body.