



Approval Code

75	356	427
428	429	

Certificate of Compliance

SUBMITTOR

Certificate Number: LR 10990-47

Revision: LR 10990-55

Date Issued: May 4, 1998

Issued To: ARCOLECTRIC SWITCHES PLC
Central Avenue
East Molesey
Surrey, England KT8 2RF

The products listed below are eligible to bear the CSA Mark.

NOTE: The "NRTL/C" indicator also appears adjacent to the CSA Mark.

Issued By: G. Raymond, Eng.
Montreal, PQ, CANADA

Signature

PRODUCTS

CLASS 6241 10 - SWITCHES - Snap - Special Use
CLASS 6241 90 - SWITCHES - Snap - Special Use

Switches, special use, manual, toggle with bat-handle actuator (plastic or metal), rated 250V, 60Hz, Series 17XX:

Ratings: 1700, 1710, single pole, 20A @ 250V ac N.I., 1 hp @ 250V ac, 1/2 hp @ 125V ac;
1720, single pole, 20A @ 250V ac N.I., 1/2 hp @ 250V ac, 1/4 hp @ 125V ac;
1750, 1760, double pole, 16A @ 250V ac N.I., 1hp @ 250V ac, 1/2 hp @ 125V ac;
1770, double pole, 16A @ 250V ac N.I., 1/2 hp @ 250V ac, 1/4 hp @ 125V ac;
1784, 1789, single pole, 5A @ 250V ac. N.I.

Note: Model designations may have prefix and suffix letters.

The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.

Certificate No: LR 10990-47



Date: May 4, 1998

Revision: LR 10990-55

Approval Code

75	356	427
428	429	

APPLICABLE STANDARDS

CSA Std C22.2 No. 55-M1986 - Special Use Switches

ANSI/UL Std No. 1054 - Special-Use Switches

Certificate No: LR 10990-47



Date: May 4, 1998

Revision: LR 10990-55

Product Certification History

Revision	Date	Description
LR 10990-48	Oct. 24/94	Removal of the NI restriction from Series 178X.
LR 10990-55	May 4, 1998	Editorial corrections to ratings.

Approval Code

75	356	427
428	429	