Product data sheet Characteristics

LV510838

Easypact CVS - CVS100E TM40D circuit breaker - 3P/3D





Main

Product or component type	Circuit breaker	_ ;
Device short name	CVS100E	-
Device application	Distribution	- 5
Poles description	3P	- 5
Protected poles description	3d	- 6
Earth leakage protection (Vigi add on)	Without	- <u>rail</u>
[In] rated current	40 A (40 °C)	_ ;
Breaking capacity code	E	-i+o+i
Network type	AC	- 5
[Ue] rated operational voltage	440 V AC conforming to EN/IEC 60947-2 50/60 Hz	
[Icu] Breaking capacity	50 kA Icu conforming to IEC 60947-2 at 220/240 V AC 50/60 Hz 25 kA at 380/415 V 20 kA at 440 V	l atab for date
Utilisation category	Category A	_ q
Trip unit name	TM-D	+
Trip unit technology	Thermal-magnetic	- <u>.</u>
Trip unit rating	40 A (40 °C)	ئ
Protection type	Overload protection (thermal)	di

Complementary

o o mpromornary		
Network frequency	50/60 Hz	
Control type	Toggle	
Mounting mode	Fixed	
Mounting support	Backplate	
Upside connection	Front	
Downside connection	Front	
[Ui] rated insulation voltage	690 V conforming to EN/IEC 60947-2 AC 50/60 Hz	
[Uimp] rated impulse withstand voltage	6 kV conforming to EN/IEC 60947-2	

[lcs] rated service breaking capacity	17 kA conforming to IEC 60947-2 440 V AC 50/60 Hz	
Mechanical durability	13000 cycles	
Electrical durability	4000 cycles conforming to IEC 60947-2 415 V In AC 50/60 Hz 8000 cycles In/2	
Long time pick-up adjustment type Ir	Fixed	
Long time delay adjustment type	Fixed	
Height	130 mm	
Width	75 mm	
Depth	60 mm	
Product weight	0.78 kg	

Environment

Standards	EN 60947-2
Pollution degree	3 conforming to IEC 60947-1

Offer Sustainability

Sustainable offer status	Green Premium product	
RoHS (date code: YYWW)	Compliant - since 1116 - Schneider Electric declaration of conformity	
	Schneider Electric declaration of conformity	
REACh	Reference not containing SVHC above the threshold	
	Reference not containing SVHC above the threshold	
Product environmental profile	Available	
Product end of life instructions	Available	

Contractual warranty

o management of the contract o	
Warranty period	18 months