



Certificate of Compliance

Certificate Number: LR 12730-374
KEMA Ref. 97.3347

Revision: LR 12730-374

Date Issued: August 20, 1997

Issued To: Siemens AG
Abt. ASI 2 GWA TPA
Werner von Siemens
Strasse 48
92220 AMBERG
Germany

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski
CSA Montreal

Signature

PRODUCTS

Thermal Overload Relays, Type 3RU1146, adjustable, open type, 3-pole, integral ambient compensated, replaceable thermal trip features, suitable for providing overload protection. The trip current is 125 percent of the FLA shown on dial.

RATINGS

Setting Ranges	Suffix	From	To (A)	Max Fuse
	4D	18	25	100 A
	4E	22	32	125 A
	4F	28	40	150 A
	4H	36	50	200 A
	4J	45	63	250 A
	4K	57	75	300 A
	4L	70	90	350 A
	4M	80	100	350 A

Auxiliary Contacts: B600/R300 - 1 NO + 1 NC change-over contact.

Accessory, Type 3RU1946-2AA01, connecting support.



Certificate of Compliance

Certificate Number: LR 12730-374
KEMA Ref. 97.3347

Revision: LR 12730-374

Date Issued: August 20, 1997

Notes:

- 1 The type designation may be completed with suffixes indicating setting ranges, terminal design, mounting etc.
- 2 Certified as component for use only in Certified equipment, where the acceptability of combination is to be determined by the Canadian Standards Association.
- 3 The relays are intended for use in combination with this manufacturer's Certified contactors 3TF and 3RT or for separate use.
- 4 Type 3RU1146 may be provided with Certified accessories of Type 3RU19.. including connecting support and electrical or mechanical remote reset.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements
" " " " 14 - 95 - Industrial Control Equipment