

# Statement of Test Result

**Product:** Electronic Box  
**Manufacturer:** ELSTEEL Ltd.  
Spur Road 2  
I.P.Z. Katunayeka  
Sri Lanka  
**Production site:** Same as manufacturer  
**Tested by request of:** ELSTEEL DANMARK A/S  
Fabriksvej 23  
DK-3000 Helsingør  
Torben Berthelsen  
**Model/Type ref.:** CBOX 4.6.2 and CBOX 5.6.2  
**Degree of protection:** IP 65

The apparatus has been tested according to IEC Publication 529 Second Edition 1989-11. The protection against dust ingress (IP 6X.) has been carried out according to Sub-Clause 13.4. The tests for water ingress (IP X5) have been carried out according to Sub-Clauses 14.2.5.

There was *no* ingress of water or dust in the enclosure.

UL International Demko A/S hereby confirms that the above-mentioned enclosures comply with the requirements for classifications IP 65 according to IEC 529 Second Edition 1989-11.

This Statement of Test Result replaces the previous issued Statement of Test Result no. 129169 dated 2001-04-20.

On behalf of UL International Demko A/S

Herlev, 2001-04-23



Steen Lumby  
Certification Manager

*UL International Demko A/S is a body notified to the Member States and Commission of the European Communities according to the provisions of Article 8 of the Low Voltage Directive.  
The name of UL International Demko A/S can be used in the marketing of the products.*

## UL International Demko A/S

Lyskaer 8, P.O. Box 514  
DK-2730, Herlev, Denmark  
Telephone: +45 44856565  
Fax: +45 44856500



A Subsidiary of  
**Underwriters  
Laboratories Inc.**