



Certificate of Compliance

Certificate Number: LR 73294

Date Issued: January 18, 1995

Issued To: R.S. Components Ltd.
P.O. Box 99
Corby
Northants NN17 9RS England

The products listed below are eligible to bear the CSA Mark.

Issued By: N. Graham
Toronto, ON Canada

Signature

PRODUCTS

Relays, Types 351-594, -601, -617,, -566, -572, -588, -623, -639, -645;
Cat Nos 803-039 and -045.

MARKINGS

The CSA Mark with NRTL/C, file number 73294; model designation; and any "Cautions" or other information as specified in the Certification Report.



Product Certification History

Certificate Number: LR 28197M16-41

Date Issued: January 18, 1995

Revision	Date	Issued By	Description	Description
LR 28197-41	18/01/95	N. Graham	Listee - <u>R.S. Components</u>	Submittor - <u>Finder</u>
			803-039	4051 9 012
			803-045	4061 9 012



Canadian Standards Association
Association canadienne de normalisation

CERTIFICATION RECORD

The company named below has been authorized by Canadian Standards Association to represent the products listed in this record as "CSA Certified" or "CSA Accepted", as applicable, and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

January 18, 1995(Replaces:February 4, 1994)

CLASS 3211 07 (Re-examination Service)

R.S. COMPONENTS LTD.

073294

P.O. Box 99

Corby

Northants NN17 9RS England

INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Relays, miniature size with or without dust cover, operating coils to 240V ac or 125V dc, Series RS 350, contacts 10A, 300V ac, 2.5kVA.
- Relays, Types 352-424, 352-430, miniature size with or without dust cover, operating coils to 240V ac or 125V dc, contacts 10A, 300V ac, 2.5kVA.
- Relays, Types 351-594, -601, -617, -566, -572, -588, -623, -639, -645; Cat Nos 803-039, -045, miniature size, with dust cover, operating coils to 125V dc or 240V ac, contacts spdt, 16A, 250V ac NI and/or 1/3 hp, 250V ac or 1/2 hp, 250V ac; 2pdt, 5A, 250V ac NI and/or 1/6 hp, 250V ac.
- Relays, Series 376-830, -846, -852, -802, -818, -824, miniature size, with dust cover, operating coils to 125V dc or 240V ac contacts, spdt, 16A, 250V ac NI and/or 1/3 hp, 250V ac or 1/2 hp, 250V ac, 2pdt, 5A, 250V ac NI and/or 1/6 hp, 250V ac.

General Notes:

1. The relays are Certified provided that the total load connected to the line at one time does not exceed 30A at 51-150V and 20A at 151-300V.
2. These relays are Certified for use only as components in other CSA Certified electrical equipment.
3. The series designation is completed by suffixes to indicate terminal type, number of poles, coil voltage and mechanical variations.

* * * * *