

# Electro-Pneumatic Regulator/ Electronic Vacuum Regulator



IP65

RoHS

For the stepless control of air pressure in  
proportion to electrical signals

## Serial communication specification

Applicable Fieldbus protocols



DeviceNet™



RS-232C specification

Compact and lightweight  
(Integrated communication parts)

Weight: **350 g**<sup>\*1</sup> (ITV1000)

Power consumption: **4 W**<sup>\*1</sup> or less

<sup>\*1</sup> Values for the communication type (PROFIBUS DP)



For the ITV10□0-IL

## Electro-Pneumatic Regulators

<sup>\*2</sup> Set pressure: 0.6 MPa Supply pressure: 1.0 MPa

### ITV0000 Series

p. 5

Max. flow rate

**6**<sup>\*2</sup> l/min (ANR)



### ITV1000 Series

p. 13

Grease-free specification  
(Parts in contact  
with fluid)

Max. flow rate

**200**<sup>\*2</sup> l/min (ANR)



### ITV2000 Series

p. 13

Max. flow rate

**1500**<sup>\*2</sup> l/min (ANR)



### ITV3000 Series

p. 13

Max. flow rate

**4000**<sup>\*2</sup> l/min (ANR)



## Electronic Vacuum Regulators

### ITV009□ Series

p. 39



### ITV209□ Series

p. 46



# ITV Series



CAT.EUS60-15G-UK

## Compact Electro-Pneumatic Regulator *ITV0000 Series* p. 5 IP65 equivalent

## Compact Vacuum Regulator *ITV009□ Series* p. 39

Compact

**15 mm**

Thanks to its simplified high-density circuit board design, an extremely compact product has been made possible.



Lightweight


**100 g**

**Improved space saving and weight reduction when used in a manifold**

Stations can be easily increased or decreased due to the DIN rail mounting design.




### 2 types of cable connectors




### Built-in One-touch fittings

### With error indication LED

### 2 types of brackets



- **Linearity:**  $\pm 1$  % F.S. or less
- **Hysteresis:** 0.5 % F.S. or less
- **Repeatability:**  $\pm 0.5$  % F.S. or less
- **High-speed response time:** 0.1 s (Without load)  
\* This is not a guaranteed value as it depends on the operating environment.
- **High stability**  
Sensitivity: 0.2 % F.S. or less



## Electro-Pneumatic Regulator *ITV1000/2000/3000 Series* p. 13 IP65

## Electronic Vacuum Regulator *ITV209□ Series* p. 46




ITV1000

ITV2000

ITV3000

ITV2090


- **Sensitivity:** 0.2 % F.S. or less
- **Linearity:**  $\pm 1$  % F.S. or less
- **Hysteresis:** 0.5 % F.S. or less
- **Cable connections in 2 directions**




- **Grease-free specification**  
(ITV1000 series)

### Application examples

For multi-stage control to analogue control



For electrostatic coating control



### Serial communication specification

#### Reduced wiring

Applicable Fieldbus protocols



RS-232C specification

# IO-Link Compatible Devices:


## Electro-Pneumatic Regulator ITV10□0/20□0/30□0-IL p. 13

## Electronic Vacuum Regulator ITV2090-IL p. 46

IO-Link communication enables users to check device information and monitor device status in addition to performing pressure control.



IO-Link is an open communication interface technology between the sensor/actuator and the I/O terminal that is an international standard: IEC 61131-9.



### Configuration File (IODD File\*1)

·Manufacturer ·Product part no. ·Set value

\*1 IODD File:  
IODD is an abbreviation of IO Device Description. This file is necessary for setting the device and connecting it to a master. Save the IODD file on the PC to be used to set the device prior to use.



**IO-Link Compatible Devices:**  
Electro-Pneumatic Regulator  
ITV10□0/20□0/30□0-IL  
Electronic Vacuum Regulator  
ITV2090-IL

The IO-Link master and device can be connected with one cable.

Only a single cable combining the communication wire and the power supply wire is required.

Uses 4-wire unshielded cables

Special communication cables are not necessary.

A conventional 4-wire unshielded cable can be used for the input and output of sensors, switches, etc.

(Recommended specifications: Conductor resistance 3 Ω,  
Wire-to-wire capacitance 3 nF or less, 20 m or less)

## Implement diagnostic bits in the process data.


The diagnostic bit in the cyclic process data makes it easy to find problems with the equipment.

It is possible to find problems with the equipment in real time using the cyclic (periodic) data and to monitor such problems in detail with the noncyclic (aperiodic) data.

## Application

### ● For the manufacturing of various products

The set pressure analogue value can be changed to control the indentation pressure applied to each workpiece. This allows for a variety of products to be manufactured on the same line.



### Process Data

<PD\_IN: 4 bytes>

Byte	0								1							
Bit	31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16
Value	Output pressure value (16 bits)															

Byte	2								3							
Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Value	Abnormal				Warning				Notification				SSC1			

<PD\_OUT: 2 bytes>







Byte	0								1							
Bit	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
Value	Set pressure value (16 bits)															

### Diagnosis items

- Output pressure is within the set pressure  $\pm 10\%$
- Notification of energizing time
- Residual pressure error
- Target value over range
- Pressure under range (LLL)
- Pressure over range (HHH)
- Power supply voltage drop
- Excessive power supply voltage
- Warning occurred
- Internal communication error

## Series Variations

For the stepless control of air pressure in proportion to electrical signals

	Series	Model	Set pressure range	Input signal	Port size	Page
Electro-Pneumatic Regulators	ITV0000 Series 	ITV001□	0.001 to 0.1 MPa	Current type: 4 to 20 mADC (Sink type)	Built-in One-touch fittings Metric size: Ø 4 Inch size: Ø 5/32	5
		ITV003□	0.001 to 0.5 MPa	Current type: 0 to 20 mADC (Sink type)		
		ITV005□	0.001 to 0.9 MPa	Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC		
	ITV1000 Series 	ITV101□	0.005 to 0.1 MPa	Current type: 4 to 20 mADC (Sink type) Current type: 0 to 20 mADC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC	1/8, 1/4	13
		ITV103□	0.005 to 0.5 MPa			
		ITV105□	0.005 to 0.9 MPa			
	ITV2000 Series 	ITV201□	0.005 to 0.1 MPa	Preset input (4 points/16 points) 10-bit digital input CC-Link compatible DeviceNet® compatible PROFIBUS DP compatible IO-Link compatible RS-232C communication	1/4, 3/8	13
		ITV203□	0.005 to 0.5 MPa			
		ITV205□	0.005 to 0.9 MPa			
	ITV3000 Series 	ITV301□	0.005 to 0.1 MPa		1/4, 3/8, 1/2	13
		ITV303□	0.005 to 0.5 MPa			
		ITV305□	0.005 to 0.9 MPa			
Electronic Vacuum Regulators	ITV009□ Series 	ITV009□	-1 to -100 kPa	Current type: 4 to 20 mADC (Sink type) Current type: 0 to 20 mADC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC	Built-in One-touch fittings Metric size: Ø 4 Inch size: Ø 5/32	39
	ITV209□ Series 	ITV209□	-1.3 to -80 kPa	Current type: 4 to 20 mADC (Sink type) Current type: 0 to 20 mADC (Sink type) Voltage type: 0 to 5 VDC Voltage type: 0 to 10 VDC Preset input (4 points/16 points) 10-bit digital input CC-Link compatible DeviceNet® compatible PROFIBUS DP compatible IO-Link compatible RS-232C communication	1/4	46



# CONTENTS



## Electro-Pneumatic Regulators

### ■ ITV0000 Series

How to Order .....	p. 5
Specifications .....	p. 6
Accessories (Option) .....	p. 6
Working Principle .....	p. 7
Linearity/Hysteresis, Repeatability, Pressure Characteristics, Flow Rate Characteristics .....	p. 8
Dimensions .....	p. 10

### ■ ITV1000/2000/3000 Series

How to Order .....	p. 13
Standard Specifications .....	p. 14
Communication Specifications .....	p. 14
Modular Products and Accessory Combinations .....	p. 15
Accessories (Option)/Part Nos. ....	p. 15
Working Principle .....	p. 16
Linearity, Hysteresis, Repeatability, Pressure Characteristics, Flow Rate Characteristics, Relief Characteristics .....	p. 17
Construction .....	p. 23
Dimensions .....	p. 25
Made to Order .....	p. 34

## Electronic Vacuum Regulators

### ■ ITV009□ Series

How to Order .....	p. 39
Specifications .....	p. 40
Accessories (Option) .....	p. 40
Working Principle .....	p. 41
Linearity/Hysteresis, Repeatability, Pressure Characteristics, Flow Rate Characteristics .....	p. 42
Dimensions .....	p. 43

### ■ ITV2090/2091 Series

How to Order .....	p. 46
Standard Specifications .....	p. 47
Communication Specifications .....	p. 47
Working Principle .....	p. 48
Linearity, Hysteresis, Repeatability, Pressure Characteristics, Flow Rate Characteristics .....	p. 48
Dimensions .....	p. 49

Accessories (Option) .....	p. 52
Specific Product Precautions .....	p. 53

# Compact Electro-Pneumatic Regulator *ITV0000 Series*



## How to Order

For single unit and single unit for manifold

**ITV00 1 0 - 0** [ ] [ ] [ ] **N**

**Pressure range**

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

**Power supply voltage**

0	24 VDC ±10 %
1	12 to 15 VDC

**Input signal**

0	Current type 4 to 20 mADC (Sink type)
1	Current type 0 to 20 mADC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

**Built-in One-touch fittings type**

**For single unit**

Symbol	SUP <sup>1</sup>	OUT <sup>2</sup>	EXH <sup>3</sup>
—	Metric size (Light grey)	Ø 4	
U	Inch size (Orange)	Ø 5/32"	

**For manifold**

Symbol	SUP <sup>1</sup>	OUT <sup>2</sup>	EXH <sup>3</sup>
—	Metric size (Light grey)	Ø 6	Ø 4   Ø 6
U	Inch size (Orange)	Ø 1/4"	Ø 5/32"   Ø 1/4"

**Cable connector (Option)**

N	Without cable connector
S	Straight type 3 m
L	Right angle type 2 m

**Bracket/Option for single unit only**

—	Without bracket
B	Flat bracket
C	L-bracket

**Base type**

—	For single unit
M	For manifold

## Manifold

**IITV00 - 02** [ ] - **n**

**Stations**

02	2 stations
03	3 stations
:	:
10	10 stations

**Option**

If a DIN rail longer than the specified stations is required, specify the applicable stations in two digits.  
(Max. 10 stations)  
Example) **IITV00-05-07**

**One-touch fitting size for supply/exhaust parts (End plate)**

—	Ø 6 (Light grey)
U	Ø 1/4" (Orange)

\* A DIN rail with the length specified by the number of stations is attached to the manifold. For dimensions of the DIN rail, refer to the external dimensions.

## How to Order Manifold Assembly (Example)

Indicate the part numbers of electro-pneumatic regulators to be mounted below the manifold part number.

Example)

Due to the common supply/exhaust feature, note that different pressure range combinations are not available.

**IITV00-03.....1 set (Manifold part no.)**


\*ITV0030-3MS.....2 sets (Electro-pneumatic regulator part no. (Stations 1, 2))

\*ITV0030-3ML.....1 set (Electro-pneumatic regulator part no. (Station 3))


Indicate part numbers in order starting from the first station on the D side.

Caution) Combination with having different pressure ranges is not available due to common supply/exhaust features.


The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the electro-pneumatic regulator.



## Specifications



Symbol



Model		ITV001□	ITV003□	ITV005□
Min. supply pressure		Set pressure + 0.1 MPa		
Max. supply pressure		0.2 MPa	1.0 MPa	
Set pressure range		0.001 to 0.1 MPa	0.001 to 0.5 MPa	0.001 to 0.9 MPa
Power supply	Voltage	24 VDC ±10 %, 12 to 15 VDC		
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less Power supply voltage 12 to 15 VDC type: 0.18 A or less		
Input signal	Voltage type	0 to 5 VDC, 0 to 10 VDC		
	Current type	4 to 20 mA DC, 0 to 20 mA DC (Sink type)		
Input impedance	Voltage type	Approx. 10 kΩ		
	Current type	Approx. 250 Ω		
Output signal*2	Analogue output	1 to 5 VDC (Output impedance: Approx. 1 kΩ) Output accuracy: ±6 % F.S. or less		
Linearity		±1 % F.S. or less		
Hysteresis		0.5 % F.S. or less		
Repeatability		±0.5 % F.S. or less		
Sensitivity		0.2 % F.S. or less		
Temperature characteristics		±0.12 % F.S./°C or less		
Operating temperature range		0 to 50 °C (No condensation)		
Enclosure		Equivalent to IP65*3		
Connection type		Built-in One-touch fittings		
Connection size	For single unit	Metric size	①, ②, ③: Ø 4	
		Inch size	①, ②, ③: Ø 5/32"	
	Manifold	Metric size	①, ③: Ø 6, ②: Ø 4	
		Inch size	①, ③: Ø 1/4", ②: Ø 5/32"	
Weight**1		100 g or less (Without options)		

\*1 Indicates the weight of a single unit

For IITV00-n

Total weight (g) ≤ Stations (n) x 100 + 130 (Weight of end block A, B assembly) + Weight (g) of DIN rail

\*2 When measuring ITV analogue output from 1 to 5 VDC, if the load impedance is less than 100 kΩ, the analogue output monitor accuracy of ±6 % F.S. or less may not be available. The product with an accuracy of within ±6 % is supplied upon your request. Output pressure remains unaffected.

\*3 When using under the conditions equivalent to IP65, connect the fitting or tube to the breathing hole before use. (For details, refer to "Specific Product Precautions 1" on page 53.)

\* When there is a downstream flow consumption, pressure may become unstable depending on piping conditions.

\* When the input signal is at 0 %, the exhaust solenoid valve is controlled to reduce the outlet pressure to zero. For this reason, a noise may be generated. This noise is normal and does not indicate a fault.

## Accessory (Option)/Part Nos.

### [Bracket]

Description	Part No.	Weight
Flat bracket assembly (including mounting screws)	P39800022	10
L-bracket assembly (including mounting screws)	P39800023	

\* When mounting, use a tightening torque of 0.3 N·m.

### [Cable connector]

Description	Part No.	Weight
Cable connector (4 cores)/Straight type	P398000-500-3	50
Cable connector (4 cores)/Right angle type	P398000-501-2	

### [Cable connector specifications]


P398000-500-3, P398000-501-2

Conductor	Nominal cross section	4 x AWG23
	Outside diameter	Approx. 0.72 mm
Insulator	Outside diameter	Approx. 1.14 mm
Sheath	Material	PVC
Finished outside diameter		Ø 4 mm
Min. bending radius		40 mm


## Working Principle

When the input signal rises, the air supply solenoid valve ① turns ON. Due to this, part of the supply pressure passes through the air supply solenoid valve ① and changes to output pressure. This output pressure feeds back to the control circuit ④ via the pressure sensor ③. Here, pressure corrections continue until output pressure becomes proportional to the input signal, enabling output pressure that is proportional to the input signal.

### Working Principle Diagram




### Block Diagram






## ITV001□ Series

### Linearity, Hysteresis




### Repeatability

With 50 % of signal input




### Pressure Characteristics

Set pressure: 0.05 MPa




### Flow Rate Characteristics

Supply pressure: 0.2 MPa




## ITV003□ Series

### Linearity, Hysteresis




### Repeatability

With 50 % of signal input




### Pressure Characteristics

Set pressure: 0.25 MPa




### Flow Rate Characteristics

Supply pressure: 0.6 MPa




ITV005□ Series

Linearity, Hysteresis




Repeatability

With 50 % of signal input




Pressure Characteristics

Set pressure: 0.45 MPa




Flow Rate Characteristics

Supply pressure: 1.0 MPa







## Dimensions

### For single unit




\*1 When using under the conditions equivalent to IP65, connect the fittings or tube to the breathing hole before use.  
(For details, refer to "Specific Product Precautions 1" on page 53.)



## Dimensions

### Single unit for manifold




\*1 When using under the conditions equivalent to IP65, connect the fittings or tube to the breathing hole before use. (For details, refer to "Specific Product Precautions 1" on page 53.)

\* For dimensions of the cable connector, refer to single unit on page 10.




## Dimensions

## Manifold



No.	1	2	3
1 ITV003 5	SUP	OUT	EXH

\* Stations are counted starting from the D side.



\* For dimensions of the cable connector, refer to single unit on page 10.



# Electro-Pneumatic Regulator ITV1000/2000/3000 Series



## How to Order

ITV **3** **0** **1** **0** - **0** **1**  **2**  **S**  -

### Model

1	1000 type
2	2000 type
3	3000 type

### Pressure range

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

### Power supply voltage

0	24 VDC
1	12 to 15 VDC

\* The communication models (CC, DE, PR, RC, and IL), 16 points preset input, and 10-bit digital input options are only available for the 24 VDC.

### Input signal/

#### Communication model

0	Current type 4 to 20 mADC (Sink type)
1	Current type 0 to 20 mADC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC
40	4 points preset input
52	16 points preset input (Switch output/NPN output)
53	16 points preset input (Switch output/PNP output)
60	10-bit digital input
CC	CC-Link
DE	DeviceNet®
PR	PROFIBUS DP
RC	RS-232C communication
IL	IO-Link

### Monitor output

1	Analogue output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analogue output 4 to 20 mADC (Sink type)
—	None

### Thread type

—	Rc
N	NPT
T	NPTF
F	G

### Made to order

Refer to page 15 for details.

### Pressure display unit

—	MPa
2*1	kgf/cm <sup>2</sup>
3	bar
4*1	psi
5	kPa

\*1 This product is for overseas use only according to the New Measurement Act. (The SI unit type is provided for use in Japan.) For the communication models CC, DE, PR, and RC, only “—” is available as it does not have a pressure display.

### Cable connector type

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

\* Even when a cable connector is selected, a communication cable is not included for the communication models CC, DE, and PR. Please order it separately. Refer to the table below.  
For 10-bit digital input, the right angle type cannot be selected.

### Bracket\*1

—	Without bracket
B	Flat bracket
C	L-bracket

\*1 The bracket is included.

### Port size

1	1/8 (1000 type)
2	1/4 (1000, 2000, 3000 type)
3	3/8 (2000, 3000 type)
4	1/2 (3000 type)

The simple specials system can be used to change the input and output ranges.

\* The input and output values are limited to the following ranges.

· Input signal: Current type 0 to 20 mA  
Voltage type 0 to 10 VDC  
· Output pressure: 0.005 to 0.9 MPa/5-900kPa  
Please contact your local sales representative for more details.


For communication cables, use the parts listed below (Refer to the M8/M12 connector in the **Catalogue on [www.smc.eu](http://www.smc.eu)** for details.) or order a product certified for the respective protocol (with M12 connector) separately.

Application	Communication cable part no.	Note
CC-Link compatibility	PCA-1567720 (Socket type)	A dedicated Bus adapter is included with the product.
	PCA-1567717 (Plug type)	
DeviceNet® compatibility	PCA-1557633 (Socket type)	A T-branch connector is not included with the product. *1
	PCA-1557646 (Plug type)	
PROFIBUS DP compatibility	PCA-1557688 (Socket type)	A T-branch connector is not included with the product. *1
	PCA-1557691 (Plug type)	


\*1 SMC does not provide T-branch connectors.

If required, purchase a commercially available T-branch connector.

# Electro-Pneumatic Regulator *ITV1000/2000/3000 Series*



Symbol



Rated pressure




Fig. 1 Input/output characteristics chart

## Standard Specifications

Model		ITV101□*7	ITV103□*7	ITV105□*7
		ITV201□	ITV203□	ITV205□
		ITV301□	ITV303□	ITV305□
Min. supply pressure		Set pressure + 0.1 MPa		
Max. supply pressure		0.2 MPa	1.0 MPa	
Set pressure range*1		0.005 to 0.1 MPa	0.005 to 0.5 MPa	0.005 to 0.9 MPa
Power supply	Voltage	24 VDC ±10 %, 12 to 15 VDC		
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less*8 Power supply voltage 12 to 15 VDC type: 0.18 A or less		
Input signal*8	Current type*2	4 to 20 mA DC, 0 to 20 mA DC (Sink type)		
	Voltage type	0 to 5 VDC, 0 to 10 VDC		
	Preset input	4 points (Negative common), 16 points (No common polarity)		
Input impedance	Digital input	10 bits (Parallel)		
	Current type	250 Ω or less*6		
	Voltage type	Approx. 6.5 kΩ		
	Preset input	Power supply voltage 24 VDC type: Approx. 4.7 kΩ Power supply voltage 12 VDC type: Approx. 2.0 kΩ		
	Digital input	Approx. 4.7 kΩ		
Output signal (Monitor output)*3	Analogue output	1 to 5 VDC (Output impedance: Approx. 1 kΩ) 4 to 20 mA DC (Sink type) (Output impedance: 250 Ω or less) Output accuracy ±6 % F.S. or less		
	Switch output	NPN open collector output: Max. 30 V, 80 mA PNP open collector output: Max. 80 mA		
Linearity		±1 % F.S. or less		
Hysteresis		0.5 % F.S. or less		
Repeatability		±0.5 % F.S. or less		
Sensitivity		0.2 % F.S. or less		
Temperature characteristics		±0.12 % F.S./°C or less		
Output pressure display*4		Accuracy ±2 % F.S. ±1 digit or less		
Ambient and fluid temperatures		MPa: 0.001, kgf/cm <sup>2</sup> : 0.01, bar: 0.01, psi: 0.1*5, kPa: 1		
Enclosure		0 to 50 °C (No condensation)		
Weight*8, *9		IP65		
ITV10□□		Approx. 250 g (Without options)		
ITV20□□		Approx. 350 g (Without options)		
ITV30□□		Approx. 645 g (Without options)		

\*1 Please refer to Fig. 1 for the relationship between set pressure and input. Because the max. set pressure differs for each pressure display, refer to page 58.

\*2 2-wire type 4 to 20 mA DC is not available. Power supply voltage (24 VDC or 12 to 15 VDC) is required.

\*3 Select either analogue output or switch output.

Further, when switch output is selected, select either NPN output or PNP output.

When measuring ITV analogue output from 1 to 5 VDC, if the load impedance is less than 100 kΩ, the analogue output monitor accuracy of within ±6 % (full span) may not be available. The product with the accuracy of within ±6 % is supplied upon your request. Output pressure remains unaffected.

\*4 Adjustment of numerical values such as the zero/span adjustment or preset input type is set based on the min. units for output pressure display (e.g. 0.001 to 0.500 MPa). Note that the unit cannot be changed.

\*5 The min. unit for 0.9 MPa (130 psi) types is 1 psi.

\*6 Value for the state with no over current circuit included. If an allowance is provided for an over current circuit, the input impedance varies depending on the input current. This is 350 Ω or less for an input current of 20 mA DC.

\*7 The ITV1000 series is a grease-free specification (parts in contact with fluid).

\*8 Refer to the table below for communication specifications.

\*9 Add 50 g for digital input type, 70 g for 16 points preset input type respectively.

\* The above characteristics are confined to the static state. When air is consumed on the output side, the pressure may fluctuate.

\* When using under IP65 conditions, connect the fitting or tube to the solenoid valve EXH before use. (For details, refer to "Specific Product Precautions 4" on page 56.)

## Communication Specifications (CC, DE, PR, RC, IL)

Model	ITV□□□-CC	ITV□□□-DE	ITV□□□-PR	ITV□□□-RC	ITV□□□-IL
Protocol	CC-Link	DeviceNet®	PROFIBUS DP	RS-232C	IO-Link (Class A)
Version*1	Ver. 1.10	Volume 1 (Edition 3.8), Volume 3 (Edition 1.5)	DP-V0	—	Ver. 1.1
Communication speed	156 k/625 k 2.5 M/5 M/10 Mbps	125 k/250 k/500 kbps	9.6 k/19.2 k/45.45 k 93.75 k/187.5 k/500 k 1.5 M/3 M/6 M/12 Mbps	9.6 kbps	230.4 kbps (COM3)
Configuration file*2	—	EDS	GSD	—	IODD
I/O occupation area (input/output data)	4 words/4 words, 32 bits/32 bits (per station, remote device station)	16 bits/16 bits	16 bits/16 bits	—	4 bytes/2 bytes
Communication data resolution	12 bits (4096 resolution)	12 bits (4096 resolution)	12 bits (4096 resolution)	10 bits (1024 resolution)	12 bits (4096 resolution)
Fail safe	HOLD*3/CLEAR (Switch setting)	HOLD/CLEAR (Switch setting)	CLEAR	HOLD	HOLD/CLEAR
Electric insulation*4	Insulation	Insulation	Insulation	Non-insulation	Non-insulation
Terminating resistor	Built into the product (Switch setting)	Not built into the product	Built into the product (Switch setting)	—	—
Current consumption	0.16 A or less	0.14 A or less	0.16 A or less	0.12 A or less	0.12 A or less
Weight	ITV1000	330	320	350	320
	ITV2000	430	420	450	420
	ITV3000	730	720	750	720



\*1 Please note that versions are subject to change.

\*2 Configuration files can be downloaded from the operation manual page on the SMC website: <https://www.smc.eu>

\*3 The output HOLD value when a CC-Link communications error occurs can be set based on the bit area data.

\*4 The insulation between the electrical signal of the communication system and ITV power supply

# ITV1000/2000/3000 Series



## Made to Order

(Refer to pages 34 to 38 for details.)

Symbol	Specifications
<b>X102</b>	Reverse type
<b>X224</b>	High-pressure type (SUP 1.2 MPa, OUT 1.0 MPa)
<b>X25</b>	Set pressure range: 1 to 100 kPa (Excludes the ITV3000 series)
<b>X256</b>	Analogue output, Current type (Source type)
<b>X88</b>	High-speed response time type (Excludes the ITV3000 series)
<b>X26</b>	For manifold mounting (Excludes the ITV3000 series)
<b>X410</b>	Linearity: $\pm 0.5\%$ F.S. or less
<b>X420</b>	With alarm output

- \* Manifolds are compatible with 2 to 8 stations. Please contact SMC for 9 stations or more.
- \* Products without symbols are also compatible. Please contact SMC separately.
- \* Compliant with CE/UKCA marking

Model	Bracket tightening torque
<b>ITV1000</b>	0.76 $\pm$ 0.05 N·m
<b>ITV2000/3000</b>	1.5 $\pm$ 0.05 N·m

## Modular Products and Accessory Combinations

Applicable products and accessories	Applicable model	
	ITV20□□	ITV30□□
① Air filter	AF30-A	AF40-A
② Mist separator	AFM30-A	AFM40-A
③ L-bracket	B310L-A	B410L-A
④ Spacer	Y30-A	Y40-A
⑤ Spacer with L-bracket (③ + ④)	Y30L-A	Y40L-A
⑥ Spacer with T-bracket	—	Y40T-A

\* For ITV10□□, use a modular adapter (Refer to the Catalogue on [www.smc.eu](http://www.smc.eu) for details).

## Accessories (Option)/Part Nos.

### [Bracket]

Applicable model	Description	Part no.	Weight
ITV10□□	Flat bracket assembly (including mounting screws)	P398010-600	90
ITV20□□, 30□□		P398020-600	
ITV10□□	L-bracket assembly (including mounting screws)	P398010-601	90
ITV20□□, 30□□		P398020-601	

### [Cable connector]


Input signal/ Communication model	Cable connector (Shipped together)			Weight
	Cable specifications	Power supply	Communication (For signal)	
Current type Voltage type 4 points preset input IO-Link	Straight type 3 m	P398020-500-3		180 each
	Right angle type 3 m	P398020-501-3		
16 points preset input RS-232C communication	Straight type 3 m	P398020-500-3	P398020-502-3	
	Right angle type 3 m	P398020-501-3	P398020-503-3	
10-bit digital input	Straight type 3 m	INI-398-0-59		310
CC-Link PROFIBUS DP DeviceNet®	Straight type 3 m	P398020-500-3	Please order separately. Refer to page 13.	180
	Right angle type 3 m	P398020-501-3		

### [Bus adapter]


Applicable model	Description	Part no.	Weight
<b>CC-Link</b>	<b>Bus adapter (Included with the product)</b>	EX9-ACY00-MJ	35

## Dimensions

### Flat bracket



### L-bracket






## Working Principle

When the input signal rises, the air supply solenoid valve ① turns ON, and the exhaust solenoid valve ② turns OFF. Therefore, supply pressure passes through the air supply solenoid valve ① and is applied to the pilot chamber ③. The pressure in the pilot chamber ③ increases and operates on the upper surface of the diaphragm ④.


As a result, the air supply valve ⑤ linked to the diaphragm ④ opens, and a portion of the supply pressure becomes output pressure.

This output pressure feeds back to the control circuit ⑧ via the pressure sensor ⑦. Here, a correct operation functions until the output pressure is proportional to the input signal, making it possible to always obtain output pressure proportional to the input signal.

### Working Principle Diagram




### Block Diagram




# ITV1000/2000/3000 Series

## ITV101□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.05 MPa



### Flow Rate Characteristics


Supply pressure: 0.2 MPa



### Relief


### Characteristics

Back pressure: 0.2 MPa




## ITV201□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.05 MPa



### Flow Rate Characteristics


Supply pressure: 0.2 MPa



### Relief


### Characteristics

Back pressure: 0.2 MPa




## ITV301□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.05 MPa




### Flow Rate Characteristics

Supply pressure: 0.2 MPa



### Relief Characteristics


Back pressure: 0.2 MPa




# ITV1000/2000/3000 Series

## ITV103□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.2 MPa




### Flow Rate Characteristics

Supply pressure: 0.7 MPa




### Relief Characteristics

Back pressure: 0.7 MPa




## ITV203□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.2 MPa




### Flow Rate Characteristics

Supply pressure: 0.7 MPa



### Relief Characteristics


Back pressure: 0.7 MPa






## ITV303□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.2 MPa




### Flow Rate Characteristics

Supply pressure: 0.7 MPa



### Relief Characteristics


Back pressure: 0.7 MPa




# ITV1000/2000/3000 Series

## ITV105□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.4 MPa



### Flow Rate Characteristics


Supply pressure: 1.0 MPa



### Relief


### Characteristics

Back pressure: 1.0 MPa




## ITV205□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.4 MPa



### Flow Rate Characteristics


Supply pressure: 1.0 MPa



### Relief


### Characteristics

Back pressure: 1.0 MPa




## ITV305□ Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: 0.4 MPa




### Flow Rate Characteristics

Supply pressure: 1.0 MPa



### Relief Characteristics


Back pressure: 1.0 MPa



# ITV1000/2000/3000 Series

## Construction

### ITV1000




#### Main Component Parts

No.	Description	Material
◆ 1	Body	Aluminium alloy
2	Cover	Aluminium alloy
◆ 3	Valve guide	Resin
◆ 4	Diaphragm assembly	Aluminium alloy
		HNBR
		Steel
5	Seal	NBR
6	Bowl assembly	Resin
		Silicone rubber
7	Sub-plate	Resin
8	Seal	NBR
9	Control circuit assembly	—
◆ 10	Bumper	NBR
◆ 11	Valve	Stainless steel
		HNBR
◆ 12	Guide retainer	Aluminium alloy
13	Solenoid valve	—
◆ 14	O-ring	HNBR
15	Cross recessed round head screw	Steel
◆ 16	Flat washer	Stainless steel

\* Parts in contact with fluid are indicated with a mark ◆.

### ITV2000




#### Main Component Parts

No.	Description	Material
◆ 1	Body	Aluminium alloy
◆ 2	Intermediate body	Aluminium alloy
3	Cover	Aluminium alloy
◆ 4	Valve guide	Aluminium alloy
◆ 5	Valve (Supply valve)	HNBR/Brass
◆ 6	Valve (Exhaust valve)	HNBR/Brass
◆ 7	Valve spring	Stainless steel
◆ 8	Valve spring	Stainless steel
◆ 9	Diaphragm assembly	Stainless steel
		Aluminium alloy
		HNBR
		Steel
◆ 10	Seal	NBR
◆ 11	Bias spring	Stainless steel
◆ 12	O-ring	NBR
◆ 13	Cotter	Stainless steel
◆ 14	Wear ring	Resin
15	Seal	NBR
16	Bowl assembly	Resin
		Silicone rubber
17	Sub-plate	Resin
18	Seal	NBR
19	Control circuit assembly	—
20	Solenoid valve	—
◆ 21	O-ring	NBR
22	O-ring	NBR
23	Cross recessed round head screw	Steel

\* Parts in contact with fluid are indicated with a mark ◆.

## Construction

### ITV3000



### Main Component Parts

No.	Description	Material
1	Cover	Aluminium alloy
◆ 2	Body	Aluminium alloy
◆ 3	Valve guide	Aluminium alloy
◆ 4	Bias spring	Stainless steel
◆ 5	Intermediate body	Aluminium alloy
◆ 6	Diaphragm assembly	HNBR
		Stainless steel
		Aluminium alloy
		Steel
◆ 7	Valve (Supply valve)	HNBR/Brass
◆ 8	Valve (Exhaust valve)	HNBR/Brass
◆ 9	Valve spring	Stainless steel
◆ 10	Seal	NBR
11	Seal	NBR
◆ 12	Rod guide	Brass
◆ 13	O-ring retainer	Aluminium alloy
14	Seal	NBR
15	Bowl assembly	Resin
		Silicone rubber
16	Sub-plate	Resin
17	Seal	NBR
18	Control circuit assembly	—
19	Solenoid valve	—
20	O-ring	NBR
◆ 21	O-ring	NBR
◆ 22	O-ring	NBR
23	Cross recessed round head screw	Steel
◆ 24	Wear ring	Resin


\* Parts in contact with fluid are indicated with a mark ◆.

# ITV1000/2000/3000 Series


## Dimensions

ITV10□□

Flat bracket




L-bracket




## Dimensions (16 points preset input, 10-bit digital input, CC-Link, DeviceNet®)


### 16 points preset input




### 10-bit digital input



### CC-Link: ITV10□0-CC



### DeviceNet®: ITV10□0-DE



\* Dimensions not shown are the same as on page 25.


\* Dimensions not shown are the same as on page 25.



# ITV1000/2000/3000 Series


## Dimensions (PROFIBUS DP, RS-232C, IO-Link)

### PROFIBUS DP: ITV10□0-PR




\* Dimensions not shown are the same as on page 25.

### RS-232C: ITV10□0-RC



\* Dimensions not shown are the same as on page 25.



### IO-Link: ITV10□0-IL



### With power cable connector

\* ITV10□0- common dimensions

52  
53  
CC  
DE  
PR  
RC







\* Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 13.)

\* Do not attempt to rotate, as the cable connector does not turn.


## Dimensions

ITV20□□



Flat bracket



\* Do not attempt to rotate, as the cable connector does not turn.




L-bracket




# ITV1000/2000/3000 Series

## Dimensions (16 points preset input, 10-bit digital input, CC-Link, DeviceNet®)


### 16 points preset input




### 10-bit digital input



### CC-Link: ITV20□0-CC



### DeviceNet®: ITV20□0-DE




\* Dimensions not shown are the same as on page 28.

\* Dimensions not shown are the same as on page 28.


## Dimensions (PROFIBUS DP, RS-232C, IO-Link)

### PROFIBUS DP: ITV20□0-PR




\* Dimensions not shown are the same as on page 28.

### RS-232C: ITV20□0-RC





\* Dimensions not shown are the same as on page 28.

### IO-Link: ITV20□0-IL



## With power cable connector

\* ITV20□0-  
52  
53  
CC  
DE  
PR  
RC common dimensions



\* Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 13.)




\* Do not attempt to rotate, as the cable connector does not turn.

# ITV1000/2000/3000 Series


## Dimensions

ITV30□□



Flat bracket



\* Do not attempt to rotate, as the cable connector does not turn.




L-bracket




## Dimensions (16 points preset input, 10-bit digital input, CC-Link, DeviceNet®)


### 16 points preset input




### 10-bit digital input



### CC-Link: ITV30□-CC



### DeviceNet®: ITV30□-DE




\* Dimensions not shown are the same as on page 31.

\* Dimensions not shown are the same as on page 31.

# ITV1000/2000/3000 Series


## Dimensions (PROFIBUS DP, RS-232C, IO-Link)

### PROFIBUS DP: ITV30□-PR




\* Dimensions not shown are the same as on page 31.

### RS-232C: ITV30□-RC





\* Dimensions not shown are the same as on page 31.

### IO-Link: ITV30□0-IL



### With power cable connector

\* ITV30□0-CC, DE, PR, RC common dimensions



\* Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 13.)

\* Do not attempt to rotate, as the cable connector does not turn.




### 1 Reverse Type

In accordance with the input signal, the inverse proportional pressure is output.

ITV10   -         - X102

ITV20   -          - X102

ITV30   -          - X102



Input/output characteristics chart

- \* The  in the part numbers indicate the model nos. of the standard products.
- \* Excludes the preset input type and the digital input type
- \* For communication models, contact SMC for availability.

### 2 High-Pressure Type (SUP 1.2 MPa, OUT 1.0 MPa)

ITV10   -          - X224

ITV20   -          - X224

ITV30   -          - X224

- \* For the preset input type, the digital input type, and communication models, contact SMC for availability.

### 3 Set Pressure Range: 1 to 100 kPa

ITV10   -          - X25

ITV20   -          - X25

- \* For the preset input type, the digital input type, and communication models, contact SMC for availability.

### 4 Analogue Output, Current Type (Source Type)


Monitor output is analogue output from 4 to 20 mADC (source type).

ITV10   -          - X256

ITV20   -          - X256

ITV30   -          - X256

#### Monitor output wiring diagram



### 5 With Gauge Port


It is possible to check the outlet pressure when the product is in a de-energised state.

ITV10   -          - X400

ITV20   -          - X400

ITV30   -          - X400

Model	G port (Rc, NPT, NPTF, G)
ITV1000 type	1/8
ITV2000 type	1/8
ITV3000 type	1/4



# ITV1000/2000/3000 Series

## 5 High-Speed Response Time Type

Pressure response with no load is approx. 0.1 s.

- \* This is not a guaranteed value as it depends on the operating environment.
- \* When the input signal is at 0 %, the exhaust solenoid valve is controlled to reduce the outlet pressure to zero. For this reason, a noise may be generated. This noise is normal and does not indicate a fault.
- \* When operating for the first time, be sure that the power supply voltage and supply pressure are appropriate in relation to the operating environment and conditions.
- \* For this product, by conducting the procedure described below (steps A to D), the parameters compatible with the power supply voltage and supply pressure in use can be obtained.

If the desired output pressure values cannot be reached due to fluctuations in the operating conditions, etc., perform this operation.

A) Change the power supply voltage in use by  $\pm 0.4$  VDC or more.

B) After inputting the supply pressure used on the inlet side of the ITV, adjust the input signal as described below.

(0 %  $\rightarrow$  100 %  $\rightarrow$  0 %) (Change it gradually, waiting 10 s or more between each adjustment.)

\*\* Please contact SMC if difficulty inputting signals occurs.

C) Change the power supply voltage according to the operating conditions/requirements, and repeat step B.

D) Input the power supply voltage and a 0 % signal, and retain for 6 minutes or more. (Supply pressure is not required.)

When re-obtaining the parameters, we recommend operating with the air sealed in the piping in order to reliably reach the set pressure. In addition, if step A above cannot be carried out, it is possible to conduct an "Initialise" operation as described in the operation manual in order to reset the parameters of the product to those set at the time of shipment. When conducting an "Initialise" operation, the min. set pressure (F\_1) and the max. set pressure (F\_2) will be reset.

- \* There is no gain or sensitivity adjustment function.

**ITV 2 0 1 0 - 0 1 2 S - X88**

**Model**

1	1000 type
2	2000 type

**Pressure range**

1	0.1 MPa
3	0.5 MPa
5	0.9 MPa

**Power supply voltage**

0	24 VDC
1	12 to 15 VDC

**Input signal**

0	Current type 4 to 20 mADC (Sink type)
1	Current type 0 to 20 mADC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

**Monitor output**

1	Analogue output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analogue output 4 to 20 mADC (Sink type)

**Thread type**

—	Rc
N	NPT
T	NPTF
F	G

**Pressure display unit**

—	MPa
2*1	kgf/cm <sup>2</sup>
3	bar
4*1	psi
5	kPa

\*1 This product is for overseas use only according to the New Measurement Act. (The SI unit type is provided for use in Japan.)

**Cable connector type**

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

**Bracket\*1**

—	Without bracket
B	Flat bracket
C	L-bracket

\*1 The bracket is included.


**Port size**

1	1/8 (1000 type)
2	1/4 (1000, 2000 type)
3	3/8 (2000 type)

## 6 Manifold Specifications (Excludes the ITV3000 series)

2 through 8-station manifold

### How to Order Manifolds



### How to Order for Manifold Mounting


ITV **1** 0 **1** **1** - **1** **1** **1** - X26  
 ITV **2** 0 **1** **1** - **2** **1** **1** - X26

- \* The □ in the part numbers indicate the model nos. of the standard products.
- \* For communication models, contact SMC for availability.
- \* The thread type is Rc only.
- \* For the ITV1000 series, the port size is 1/8 only.
- \* For the ITV2000 series, the port size is 1/4 only.
- \* The bracket accessory cannot be selected.
- \* Not applicable to the ITV3000 series

IITV20-02-3 .....1 set (3-station manifold base part no.)  
 \*ITV1030-311S-X26 .....1 set (Electro-pneumatic regulator part no.)\*<sup>2</sup>  
 \*P398020-13 .....1 set (Blanking plate assembly part no.)  
 \*ITV2050-212S-X26 .....1 set (Electro-pneumatic regulator part no.)\*<sup>2</sup>  
 ↳ The asterisk denotes the symbol for the assembly. Prefix it to the part numbers of the electro-pneumatic regulator, etc.

### How to Order Manifold Assemblies

#### Example



\* Refer to the table below for possible mixed combination.


Model	ITV101□	ITV103□	ITV105□	ITV201□	ITV203□	ITV205□
ITV101□	●	—	—	●	—	—
ITV103□	—	●	●	—	●	●
ITV105□	—	●	●	—	●	●
ITV201□	●	—	—	●	—	—
ITV203□	—	●	●	—	●	●
ITV205□	—	●	●	—	●	●

- \*<sup>1</sup> Electro-pneumatic regulators are counted starting from station 1 on the left side with the OUT ports in the front.
- \*<sup>2</sup> The port size for mounted electro-pneumatic regulators is Rc1/8 (ITV1000), Rc1/4 (ITV2000) only.
- \* When there is a large number of stations, use piping with the largest possible inside diameter for the supply side, such as steel piping.
- \* The use of the straight type cable connector is recommended. To mount right angle type, be certain to check that no possible interference occurs.
- \* When mounting a blanking plate and the regulator with a different pressure set, please inform SMC of the order of a manifold station beside a purchase order.

# ITV1000/2000/3000 Series

## 7 Linearity: $\pm 0.5\%$ F.S. or Less

Application examples: Polishing equipment and peripheral equipment for wafers, LCD glasses, colour filters, etc.



The graph shown above is a typical example. (This graph shows that the output pressure curve is in a negative range when compared to the ideal line.)

## Specifications

<b>Fluid</b>		Air
<b>Min. supply pressure</b>		Set pressure + 0.1 MPa
<b>Max. supply pressure</b>		1.0 MPa (Pressure range 0.1 MPa type: 0.2 MPa)
<b>Proof pressure</b>	(Supply side)	1.5 MPa (Pressure range 0.1 MPa type: 0.3 MPa)
	(Output side)	1 MPa (Pressure range 0.1 MPa type: 0.2 MPa)
<b>Set pressure range</b>		1: 0.005 to 0.1 MPa, 3: 0.005 to 0.5 MPa, 5: 0.005 to 0.9 MPa
<b>Power supply voltage</b>		0: 24 VDC $\pm 10\%$ , 1: 12 to 15 VDC
<b>Current consumption</b>		0.12 A or less (24 VDC $\pm 10\%$ type) 0.18 A or less (12 to 15 VDC type)
<b>Input signal</b>		0: 4 to 20 mA, 1: 0 to 20 mA, 2: 0 to 5 VDC, 3: 0 to 10 VDC
<b>Input impedance</b>		Voltage type: Approx. 6.5 k $\Omega$ , Current type: 250 $\Omega$ or less
<b>Output signal</b>		Analogue output: 1 to 5 VDC/4 to 20 mA DC, Switch output (NPN/PNP)
<b>Linearity</b>		$\pm 0.5\%$ F.S. or less
<b>Hysteresis</b>		0.5 % F.S. or less
<b>Repeatability</b>		$\pm 0.5\%$ F.S. or less
<b>Sensitivity</b>		0.2 % F.S. or less
<b>Temperature characteristics</b>		$\pm 0.12\%$ F.S./ $^{\circ}\text{C}$ or less
<b>Output pressure display</b>	<b>Accuracy</b>	$\pm 2\%$ F.S. $\pm 1$ digit or less
	<b>Min. unit</b>	MPa: 0.001, kgf/cm <sup>2</sup> : 0.01, bar: 0.01, psi: 0.1, kPa: 1
<b>Ambient and fluid temperatures</b>		0 to 50 $^{\circ}\text{C}$ (No condensation)
<b>Enclosure</b>		IP65
<b>Weight</b>		ITV10□□: Approx. 250 g, ITV20□□: Approx. 350 g, ITV30□□: Approx. 645 g (Without brackets)

The above characteristics (specifications) are confined to the static state. When air is consumed on the output side, the pressure may fluctuate.

## 8 With Alarm Output

Alarm is output if the set pressure is not reached or maintained for 5 seconds or more.

**Application examples:** Pressure management for thrust control, etc.





Fig. 1 Alarm output range




Fig. 2 Relationship between output pressure and alarm output

## Specifications

<b>Fluid</b>	Air	
<b>Min. supply pressure</b>	Set pressure + 0.1 MPa	
<b>Max. supply pressure</b>	1.0 MPa (Pressure range 0.1 MPa type: 0.2 MPa)	
<b>Proof pressure</b>	(Supply side)	1.5 MPa (Pressure range 0.1 MPa type: 0.3 MPa)
	(Output side)	1 MPa (Pressure range 0.1 MPa type: 0.2 MPa)
<b>Set pressure range</b>	1: 0.005 to 0.1 MPa, 3: 0.005 to 0.5 MPa, 5: 0.005 to 0.9 MPa	
<b>Power supply voltage</b>	0: 24 VDC $\pm 10\%$ , 1: 12 to 15 VDC	
<b>Current consumption</b>	0.12 A or less (24 VDC $\pm 10\%$ type)	
	0.18 A or less (12 to 15 VDC type)	
<b>Input signal</b>	0: 4 to 20 mA, 1: 0 to 20 mA, 2: 0 to 5 VDC, 3: 0 to 10 VDC	
<b>Input impedance</b>	Voltage type: Approx. 6.5 k $\Omega$ , Current type: 250 $\Omega$ or less	
<b>Output signal</b>	Alarm output (NPN/PNP)	
<b>Linearity</b>	$\pm 1.0\%$ F.S. or less	
<b>Hysteresis</b>	0.5 % F.S. or less	
<b>Repeatability</b>	$\pm 0.5\%$ F.S. or less	
<b>Sensitivity</b>	0.2 % F.S. or less	
<b>Temperature characteristics</b>	$\pm 0.12\%$ F.S./ $^{\circ}\text{C}$ or less	
<b>Output pressure display</b>	<b>Accuracy</b>	$\pm 2\%$ F.S. $\pm 1$ digit or less
	<b>Min. unit</b>	MPa: 0.001, kgf/cm <sup>2</sup> : 0.01, bar: 0.01, psi: 0.1, kPa: 1
<b>Ambient and fluid temperatures</b>	0 to 50 $^{\circ}\text{C}$ (No condensation)	
<b>Enclosure</b>	IP65	
<b>Weight</b>	ITV10□□: Approx. 250 g, ITV20□□: Approx. 350 g, ITV30□□: Approx. 645 g (Without brackets)	

The above characteristics (specifications) are confined to the static state. When air is consumed on the output side, the pressure may fluctuate.

# Compact Vacuum Regulator ITV009□ Series



## How to Order

For single unit and single unit for manifold

ITV00 9 0 - 3 □ □ □ N

**Pressure range**

9	-100 kPa
---	----------

**Power supply voltage**

0	24 VDC ±10 %
1	12 to 15 VDC

**Input signal**

0	Current type 4 to 20 mA DC (Sink type)
1	Current type 0 to 20 mA DC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC

**Built-in One-touch fittings type**  
For single unit

Symbol	VAC[1]	OUT[2]	ATM[3]
—	Metric size (Light grey)	Ø 4	
U	Inch size (Orange)	Ø 5/32"	



For manifold

Symbol		VAC <sup>1</sup>	OUT <sup>2</sup>	ATM <sup>3</sup>
—	Metric size (Light grey)	Ø 6	Ø 4	Ø 6
U	Inch size (Orange)	Ø 1/4"	Ø 5/32"	Ø 1/4"

**Cable connector (Option)**

N	Without cable connector
S	Straight type 3 m
L	Right angle type 2 m

**Bracket/Option for single unit only**

	Without bracket
B	Flat bracket 
C	L-bracket 

**Base type**

—	For single unit
M	For manifold

Manifold

IITV00 - 02 □ - n

**Stations**

02	2 stations
03	3 stations
:	:
10	10 stations

**Option**

If a DIN rail longer than the specified stations is required, specify the applicable stations in two digits.  
(Max. 10 stations)  
Example) IITV00-05-07

**One-touch fitting size for supply/exhaust parts (End plate)**

—	Ø 6 (Light grey)
U	Ø 1/4" (Orange)

\* A DIN rail with the length specified by the number of stations is attached to the manifold. For dimensions of the DIN rail, refer to the external dimensions.

## How to Order Manifold Assembly (Example)

Indicate the part numbers of vacuum regulators to be mounted below the manifold part number.

Example)

Due to the common supply/exhaust feature, note that different pressure range combinations are not available.

**IITV00-03.....1 set (Manifold part no.)**


\*ITV0090-3MS.....2 sets (Vacuum regulator part no. (Stations 1, 2))

\*ITV0090-3ML.....1 set (Vacuum regulator part no. (Station 3))


Indicate part numbers in order starting from the first station on the D side.

Caution) Combination with having different pressure ranges is not available due to common supply/exhaust features.


The asterisk denotes the symbol for the assembly.  
Prefix it to the part numbers of the vacuum regulator.



## Specifications



Symbol



Model		ITV009□	
Min. supply pressure		Set pressure – 1 kPa	
Max. supply pressure		–101 kPa	
Set pressure range		–1 to –100 kPa	
Power supply	Voltage	24 VDC ±10 %, 12 to 15 VDC	
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less Power supply voltage 12 to 15 VDC type: 0.18 A or less	
Input signal	Voltage type	0 to 5 VDC, 0 to 10 VDC	
	Current type	4 to 20 mA DC, 0 to 20 mA DC (Sink type)	
Input impedance	Voltage type	Approx. 10 kΩ	
	Current type	Approx. 250 Ω	
Output signal*2	Analogue output	1 to 5 VDC (Output impedance: Approx. 1 kΩ) Output accuracy: ±6 % F.S. or less	
Linearity		±1 % F.S. or less	
Hysteresis		0.5 % F.S. or less	
Repeatability		±0.5 % F.S. or less	
Sensitivity		0.2 % F.S. or less	
Temperature characteristics		±0.12 % F.S./°C or less	
Operating temperature range		0 to 50 °C (No condensation)	
Enclosure		IP65 equivalent*3	
Connection type		Built-in One-touch fittings	
Connection size	For single unit	Metric size	①, ②, ③: Ø 4
		Inch size	①, ②, ③: Ø 5/32"
	Manifold	Metric size	①, ③: Ø 6, ②: Ø 4
		Inch size	①, ③: Ø 1/4", ②: Ø 5/32"
Weight*1		100 g or less (Without options)	

\*1 Indicates the weight of a single unit

For ITV00-n

Total weight (g)  $\leq$  Stations (n)  $\times$  100 + 130 (Weight of end block A, B assembly) + Weight (g) of DIN rail

\*2 When measuring ITV analogue output from 1 to 5 VDC, if the load impedance is less than 100 k $\Omega$ , the analogue output monitor accuracy of  $\pm 6\%$  F.S. or less may not be available.

The product with an accuracy of within  $\pm 6\%$  is supplied upon your request.

Output pressure remains unaffected.

\*3 When using under the conditions equivalent to IP65, connect the fitting or tube to the breathing hole before use. (For details, refer to "Specific Product Precautions 1" on page 53.)

\* When there is a downstream flow consumption, pressure may become unstable depending on piping conditions.

\* When the power is turned on, a noise may be generated. This noise is normal and does not indicate a fault.

## Accessory (Option)/Part Nos.

### [Bracket]

Description	Part No.	Weight
Flat bracket assembly (including mounting screws)	P39800022	10
L-bracket assembly (including mounting screws)	P39800023	

\* When mounting, use a tightening torque of 0.3 N·m.

### [Cable connector]

Description	Part No.	Weight
Cable connector (4 cores)/Straight type	P398000-500-3	50
Cable connector (4 cores)/Right angle type	P398000-501-2	

### [Cable connector specifications]

P398000-500-3, P398000-501-2


Conductor	Nominal cross section	4 x AWG23
	Outside diameter	Approx. 0.72 mm
Insulator	Outside diameter	Approx. 1.14 mm
Sheath	Material	PVC
Finished outside diameter		$\varnothing 4$ mm
Min. bending radius		40 mm




## Working Principle

When the input signal rises, the vacuum pressure solenoid valve ① turns ON. Due to this, part of the vacuum pressure (VAC.) passes through the vacuum pressure solenoid valve ① and changes to a vacuum pressure. This vacuum pressure feeds back to the control circuit ④ via the pressure sensor ③. Here, the vacuum pressure solenoid valve and the atmospheric pressure solenoid valve work alternately to make continuous pressure corrections until vacuum pressure becomes proportional to the input signal, thus, supplying vacuum pressure that is consistently proportional to the input signal.

### Working Principle Diagram




### Block Diagram




## ITV009 Series

### Linearity, Hysteresis




### Repeatability

With 50 % of signal input




### Pressure Characteristics

Set pressure: -10 kPa




### Flow Rate Characteristics




## Dimensions



### For single unit



### Port Location


No.	1	2	3
ITV009 	VAC	OUT	ATM

\*1 When using under the conditions equivalent to IP65, connect the fittings or tube to the breathing hole before use.  
(For details, refer to "Specific Product Precautions 1" on page 53.)



## Dimensions

### Single unit for manifold




\*1 When using under the conditions equivalent to IP65, connect the fittings or tube to the breathing hole before use.  
(For details, refer to "Specific Product Precautions 1" on page 53.)

\* For dimensions of the cable connector, refer to single unit on page 43.

Dimensions

Manifold



\* For dimensions of the cable connector, refer to single unit on page 43.

\*1 When using under the conditions equivalent to IP65, connect the fittings or tubing to the breathing hole before use. (For details, refer to "Specific Product Precautions 1" on page 53.)

	[mm]									
Manifold stations n	2	3	4	5	6	7	8	9	10	
L1	60	75	90	105	120	135	150	165	180	
L2	110.5	123	148	160.5	173	185.5	198	223	235.5	
Weight of DIN rail [g]	20	22	27	29	31	34	36	41	43	

# Electronic Vacuum Regulator

## ITV2090/2091 Series



### How to Order

ITV 209 0 - 0 1 2 S 5

#### Pressure range

9	-1.3 to -80 kPa
---	-----------------

#### Power supply voltage

0	24 VDC
1	12 to 15 VDC

\* The communication models (CC, DE, PR, RC, and IL), 16 points preset input, and 10-bit digital input options are only available for the 24 VDC.

#### Pressure display unit

5	kPa
---	-----

\* For the communication models CC, DE, PR, and RC, only "—" is available as it does not have a pressure display.

#### Cable connector type

S	Straight type 3 m
L	Right angle type 3 m
N	Without cable connector

\* Even when a cable connector is selected, a communication cable is not included for the communication models CC, DE, and PR. Please order it separately. Refer to the table below.  
For 10-bit digital input, the right angle type cannot be selected.

#### Input signal/ Communication model

0	Current type 4 to 20 mADC (Sink type)
1	Current type 0 to 20 mADC (Sink type)
2	Voltage type 0 to 5 VDC
3	Voltage type 0 to 10 VDC
40	4 points preset input
52	16 points preset input (Switch output/NPN output)
53	16 points preset input (Switch output/PNP output)
60	10-bit digital input
CC	CC-Link
DE	DeviceNet®
PR	PROFIBUS DP
RC	RS-232C communication
IL	IO-Link

#### Monitor output

1	Analogue output 1 to 5 VDC
2	Switch output/NPN output
3	Switch output/PNP output
4	Analogue output 4 to 20 mADC (Sink type)
—	None

#### Bracket\*1

—	Without bracket
B	Flat bracket
C	L-bracket

\*1 The bracket is included.

#### Port size

2	1/4
---	-----

#### Thread type

—	Rc
N	NPT
T	NPTF
F	G

For communication cables, use the parts listed below  
(Refer to the M8/M12 connector in the **Catalogue on [www.smc.eu](http://www.smc.eu)** for details.)  
or order the product certified for the respective protocol (with M12 connector) separately.

Application	Communication cable part no.	Note
CC-Link compatibility	PCA-1567720 (Socket type)	A dedicated Bus adapter is included with the product.
	PCA-1567717 (Plug type)	
DeviceNet® compatibility	PCA-1557633 (Socket type)	A T-branch connector is not included with the product. *1
	PCA-1557646 (Plug type)	
PROFIBUS DP compatibility	PCA-1557688 (Socket type)	A T-branch connector is not included with the product. *1
	PCA-1557691 (Plug type)	


\*1 SMC does not provide T-branch connectors.

If required, purchase a commercially available T-branch connector.


For the stepless control of vacuum pressure in proportion to electrical signals



Symbol



## Piping/Wiring Diagram



## Standard Specifications

Model		ITV2090	ITV2091
Min. supply vacuum pressure*1		Set pressure – 13.3 kPa	
Max. supply vacuum pressure		–101 kPa	
Set pressure range		–1.3 to –80 kPa	
Power supply	Voltage	24 VDC $\pm 10\%$	12 to 15 VDC
	Current consumption	Power supply voltage 24 VDC type: 0.12 A or less*6 Power supply voltage 12 to 15 VDC type: 0.18 A or less	
Input signal*6	Current type*2	4 to 20 mA DC, 0 to 20 mA DC (Sink type)	
	Voltage type	0 to 5 VDC, 0 to 10 VDC	
	Preset input	4 points (Negative common), 16 points (No common polarity)	
	Digital input	10 bits (Parallel)	
Input impedance	Current type	250 $\Omega$ or less*3	
	Voltage type	Approx. 6.5 k $\Omega$	
	Preset input	Power supply voltage 24 VDC type: Approx. 4.7 k $\Omega$ Power supply voltage 12 VDC type: Approx. 2.0 k $\Omega$	
	Digital input	Approx. 4.7 k $\Omega$	
Output signal*4 (Monitor output)	Analogue output	1 to 5 VDC (Output impedance: Approx. 1 k $\Omega$ ) 4 to 20 mA DC (Sink type) (Output impedance: 250 $\Omega$ or less) Output accuracy $\pm 6\%$ F.S. or less	
	Switch output	NPN open collector output: Max. 30 V, 80 mA PNP open collector output: Max. 80 mA	
Linearity		$\pm 1\%$ F.S. or less	
Hysteresis		0.5 % F.S. or less	
Repeatability		$\pm 0.5\%$ F.S. or less	
Sensitivity		0.2 % F.S. or less	
Temperature characteristics		$\pm 0.12\%$ F.S./ $^{\circ}\text{C}$ or less	
Output pressure display	Accuracy	$\pm 2\%$ F.S. $\pm 1$ digit or less	
	Unit	kPa*5 Min. display: 1	
Ambient and fluid temperatures		0 to 50 $^{\circ}\text{C}$ (No condensation)	
Enclosure		IP65	
Weight*6, *7		390 g	

- \*1 The min. supply vacuum pressure should be 13.3 kPa less than the max. vacuum pressure setting value.  
 \*2 4 to 20 mA DC is not possible with the 2-wire type. Power supply voltage (24 VDC or 12 to 15 VDC) is required.  
 \*3 Value for the state with no over current circuit included. If an allowance is provided for an over current circuit, the input impedance varies depending on the input power supply. This is 350  $\Omega$  or less for an input current of 20 mA DC.  
 When measuring ITV analogue output from 1 to 5 VDC, if the load impedance is less than 100 k $\Omega$ , the analogue output monitor accuracy of within  $\pm 6\%$  (full span) may not be available. The product with the accuracy of within  $\pm 6\%$  is supplied upon your request. Output pressure remains unaffected.  
 \*4 Either analogue output or switch output must be selected. Furthermore, when switch output is selected, either NPN output or PNP output must also be selected. Use caution that the preset input type is not equipped with an output signal function.  
 \*5 Please contact SMC regarding indication with other units of pressure.  
 \*6 Refer to the table below for communication specifications.  
 \*7 Add 50 g for digital input type, 70 g for 16 points preset input type respectively.  
 \* The product characteristics are confined to the static state.  
 Pressure may fluctuate when air is consumed at the output side.


## Communication Specifications (CC, DE, PR, RC, IL)

Model	ITV□0□0-CC□□	ITV□0□0-DE□□	ITV□0□0-PR□□	ITV□0□0-RC□□	ITV□0□0-IL□□
Protocol	CC-Link	DeviceNet®	PROFIBUS DP	RS-232C	IO-Link (Class A)
Version*1	Ver. 1.10	Volume 1 (Edition 3.8), Volume 3 (Edition 1.5)	DP-V0	—	Ver. 1.1
Communication speed	156 k/625 k 2.5 M/5 M/10 Mbps	125 k/250 k/500 kbps	9.6 k/19.2 k/45.45 k 93.75 k/187.5 k/500 k 1.5 M/3 M/6 M/12 Mbps	9.6 kbps	230.4 kbps (COM3)
Configuration file*2	—	EDS	GSD	—	IODD
I/O occupation area (input/output data)	4 words/4 words, 32 bits/32 bits (per station, remote device station)	16 bits/16 bits	16 bits/16 bits	—	4 bytes/2 bytes
Communication data resolution	12 bits (4096 resolution)	12 bits (4096 resolution)	12 bits (4096 resolution)	10 bits (1024 resolution)	12 bits (4096 resolution)
Fail safe	HOLD*3/CLEAR (Switch setting)	HOLD/CLEAR (Switch setting)	CLEAR	HOLD	HOLD/CLEAR
Electric insulation*4	Insulation	Insulation	Insulation	Non-insulation	Non-insulation
Terminating resistor	Built into the product (Switch setting)	Not built into the product	Built into the product (Switch setting)	—	—
Current consumption	0.16 A or less	0.14 A or less	0.16 A or less	0.12 A or less	0.12 A or less
Weight	ITV2090 470	460	490	460	460

- \*1 Please note that versions are subject to change.  
 \*2 Configuration files can be downloaded from the operation manual page on the SMC website: <https://www.smc.eu>  
 \*3 The output HOLD value when a CC-Link communications error occurs can be set based on the bit area data.  
 \*4 The insulation between the electrical signal of the communication system and ITV power supply



## Working Principle




## Working Principle

When the input signal increases, the vacuum pressure solenoid valve ① turns ON, and the atmospheric pressure solenoid valve ② turns OFF. Because of this, VAC. and the pilot chamber ③ are connected, the pressure in the pilot chamber ③ becomes negative and acts on the top of the diaphragm ④.

As a result, the vacuum pressure valve ⑤ which is linked to the diaphragm ④ opens, VAC. and OUT. are connected, and the set pressure becomes negative.


This negative pressure feeds back to the control circuit ⑧ via the pressure sensor ⑦. Then, a correct operation works until a vacuum pressure proportional to the input signal is reached, and a vacuum pressure is obtained which is always proportional to the input signal.

## Block Diagram




## ITV209   Series


### Linearity



### Hysteresis




### Repeatability




### Pressure Characteristics

Set pressure: -20 kPa



### Flow Rate Characteristics

Supply vacuum pressure: -100 kPa




### Flow rate characteristics measurement conditions

- Exhaust flow rate of the vacuum pump used for measurement: 500 l/min (ANR)
- Inlet vacuum pressure: -100 kPa (When outlet flow rate is 0 l/min (ANR))
- Max. flow rate: 132 l/min (ANR) (With inlet vacuum pressure at -39 kPa)



## Dimensions

### ITV209

#### Flat bracket



\* Do not attempt to rotate the cable connector, as it does not turn.




#### L-bracket




## Dimensions (16 points preset input, 10-bit digital input, CC-Link, DeviceNet®)


### 16 points preset input



### 10-bit digital input




### CC-Link: ITV2090-CC



\* Dimensions not shown are the same as on page 49.


### DeviceNet®: ITV2090-DE



\* Dimensions not shown are the same as on page 49.


## Dimensions (PROFIBUS DP, RS-232C, IO-Link)

### PROFIBUS DP: ITV2090-PR




\* Dimensions not shown are the same as on page 49.

### RS-232C: ITV2090-RC



\* Dimensions not shown are the same as on page 49.



### IO-Link: ITV2090-IL



### With power cable connector

\* ITV2090-**CC**-common dimensions

52  
53  
CC  
DE  
PR  
RC



\* Order communication cable (other than 16 points, RS-232C) separately. (Refer to page 46.)

\* Do not attempt to rotate the cable connector, as it does not turn.

# ITV1000/2000/3000/209□ Series Accessories (Option)

## Accessories (Option)/Part Nos.

### [Bracket]

Description	Part no.	Weight
Flat bracket assembly (including mounting screws)	P398020-600	90
L-bracket assembly (including mounting screws)	P398020-601	

### [Cable connector]

Applicable model	Description		Part no.	Weight
Current type Voltage type 4 points preset input IO-Link	Cable connector (4 cores)	Straight type 3 m	P398020-500-3	180
		Right angle type 3 m	P398020-501-3	
16 points preset input	Power cable (4 cores)	Straight type 3 m	P398020-500-3	
		Right angle type 3 m	P398020-501-3	
	Signal cable (5 cores)	Straight type 3 m	P398020-502-3	
		Right angle type 3 m	P398020-503-3	
10-bit digital input	Cable connector (13 cores)	Straight type 3 m	INI-398-0-59	310
CC-Link PROFIBUS DP DeviceNet®	Power cable (4 cores)	Straight type 3 m	P398020-500-3	180
		Right angle type 3 m	P398020-501-3	
RS-232C	Power cable (4 cores)	Straight type 3 m	P398020-500-3	
		Right angle type 3 m	P398020-501-3	
	Communication cable (5 cores)	Straight type 3 m	P398020-502-3	
		Right angle type 3 m	P398020-503-3	

\* For the 10-bit digital type, there is no right angle type cable connector.

\* Even when "with cable connector" is selected, the communication cable is not included in the communication model (CC, DE, and PR). Please order it separately.

### [Cable connector specifications]

#### P398020-500-3, P398020-501-3

Conductor	Nominal cross section	4 x AWG21
	Outside diameter	Approx. 0.9 mm
Insulator	Outside diameter	Approx. 1.7 mm
Sheath	Material	PVC
Finished outside diameter		Ø 6 mm
Min. bending radius		60 mm

#### P398020-502-3, P398020-503-3

Conductor	Nominal cross section	5 x AWG21
	Outside diameter	Approx. 0.9 mm
Insulator	Outside diameter	Approx. 1.7 mm
Sheath	Material	PVC
Finished outside diameter		Ø 6 mm
Min. bending radius		60 mm

#### INI-398-0-59


Conductor	Nominal cross section	16 x AWG24
	Outside diameter	Approx. 0.75 mm
Insulator	Outside diameter	Approx. 1.21 mm
Sheath	Material	PVC
Finished outside diameter		Ø 8 mm
Min. bending radius		60 mm

### [Bus adapter]


Applicable model	Description	Part no.	Weight
CC-Link	Bus adapter (Included with the product)	EX9-ACY00-MJ	35

## Dimensions

### Flat bracket



### L-bracket



Model	Bracket tightening torque
ITV1000	0.76 ±0.05 N·m
ITV2000/3000	1.5 ±0.05 N·m



## Specific Product Precautions 1

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For F.R.L. units precautions, refer to the “Handling Precautions for SMC Products” and the “Operation Manual” on the SMC website: <https://www.smc.eu>

### ITV0000/009 □ Series Precautions

#### Air Supply

#### Warning

1. Please consult with SMC when using the product in applications other than compressed air.
2. Do not use compressed air that contains chemicals, synthetic oils that include organic solvents, salt, corrosive gases, etc., as doing so may result in a malfunction.

#### Caution

1. Install an air filter near this product on the supply side. Select an air filter with a filtration size of 5  $\mu\text{m}$  or smaller.
2. Compressed air that contains a large amount of drainage can result in the malfunction of this product and other pneumatic equipment. Therefore, take appropriate measures to ensure air quality, such as by providing an aftercooler, air dryer, or water separator.
3. If excessive carbon dust is generated by the compressor, it may adhere to the inside of this product and cause it to malfunction.



Refer to the “SMC Air Preparation System” for further details on compressed air quality.

#### Wiring


#### Caution

Connect the cable to the connector on the body with the wiring arranged as shown below. Proceed carefully, as incorrect wiring can result in damage.

Further, use DC power with sufficient capacity and a low ripple.




Terminal no.	1	2	3	4
Lead wire colour	Brown	White	Blue	Black
Wiring	Power	Signal	COM	Monitor



\*1 A right angle type cable is also available. The entry direction for the right angle type connector is downward (SUP port side). Never turn the connector as it is not designed to turn. Using force to turn the connector will damage the connector coupling.


#### Wiring diagrams

##### Current signal type



Vs : Power supply 24 VDC  $\pm 10\%$   
12 to 15 VDC  
A : Input signals 4 to 20 mADC  
0 to 20 mADC


##### Voltage signal type




Vs : Power supply 24 VDC  $\pm 10\%$   
12 to 15 VDC  
Vin : Input signals 0 to 5 VDC  
0 to 10 VDC

#### Monitor output wiring diagram

##### Analogue output, voltage type



##### Monitor output (analogue output) characteristics diagram



#### Handling

#### Caution

1. Do not use a lubricator on the supply side of this product, as doing so may result in a malfunction. When lubrication of terminal equipment is necessary, connect a lubricator on the output side of this equipment.
2. If electric power is shut off while pressure is being applied, pressure will be retained on the output side.

However, this output pressure is held only temporarily and is not guaranteed. If exhausting of this pressure is desired, shut off the power after reducing the set pressure, and discharge the air using a residual pressure exhaust valve, etc.

3. If the power to this product is cut off due to a power failure, etc., when it is in a controlled state, the output pressure will be retained temporarily. Handle carefully when operating with output pressure released to the atmosphere, as air will continue to flow out.
4. If supply pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and a humming noise may be generated.

Since the life of the product may be shortened, shut off the power supply also when supply pressure is shut off.

5. This product is adjusted for each specification at the time of shipment from the factory. Avoid careless disassembly or removal of parts, as failure to do so may result in a malfunction.
6. The optional cable connector is a 4-wire type. When the monitor output (analogue output) is not being used, keep it from touching the other wires as doing so may result in a malfunction.
7. Please note that the right angle cable does not rotate and is limited to only one entry direction.
8. Take the following steps to avoid malfunction due to noise.


- 1) Remove power supply noise during operation by installing a line filter, etc., in the AC power line.
- 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors, power lines, etc.
- 3) Be sure to implement protective measures against load surge for induction loads (solenoid valves, relays, etc.).

9. The product characteristics are confined to the static state. When air is consumed on the output side, and especially used in the system with large leakage, pressure cannot approach the set pressure and the service life is drastically shortened with a humming noise of the solenoid valve.

10. For details on the handling of this product, refer to the operation manual which is included with the product.

11. In locations where the body is exposed to water, dust, etc., there is a possibility that moisture or dust could enter the body through the breathing hole.

Mount a fitting and tube (M-3AU-3 fitting and TIU01□-□□ tube recommended) onto the breathing hole and run the tube to a location not exposed to moisture, dust, etc.





# Specific Product Precautions 2

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For F.R.L. units precautions, refer to the “Handling Precautions for SMC Products” and the “Operation Manual” on the SMC website: <https://www.smc.eu>

### ITV0000/009 □ Series Precautions

#### Handling

#### ⚠ Caution

12. If this product will be used in a sealed environment, such as inside an inspection box, a ventilation fan should be installed to ensure adequate ventilation as this product can generate heat in some operating conditions. When the power is turned on, a noise may be generated as a means of checking the operating condition of the solenoid valve. This noise is normal and does not indicate a fault.

13. Each product needs to be powered by one power supply unit.

The wiring of this product has the same common between the GND for power and the signals; there is a possibility that a wrong current occurs and prevents a proper operation if one power supply unit controls multiple electro-pneumatic regulators.

14. This product does not have a shut-off valve function. If air pressure is supplied without electric power being applied, output pressure may increase to the pressure equivalent of the supply pressure. Operate the system to shut off the supply pressure when not operating the product.

15. For this product, by conducting the procedure described below (steps A to D), the parameters compatible with the power supply voltage and supply pressure in use can be obtained.

If the desired output pressure values cannot be reached due to fluctuations in the operating conditions, etc., perform this operation.

A) Change the power supply voltage in use by  $\pm 0.4$  VDC or more.

B) After inputting the supply pressure used on the inlet side of the ITV, adjust the input signal as described below.

(0 %  $\rightarrow$  100 %  $\rightarrow$  0 %) (Change it gradually, waiting 10 s or more between each adjustment.)

\* Please contact SMC if difficulty inputting signals occurs.

C) Change the power supply voltage according to the operating conditions/requirements, and repeat step B.

D) Input the power supply voltage and a 0 % signal, and retain for 6 minutes or more. (Supply pressure is not required.)

While conducting the procedure stated above, noise may be generated by the solenoid valve. However, this does not affect the obtainment of the parameters. In addition, be sure to conduct the procedure with the air sealed in the piping.

#### Return of Product

#### ⚠ Warning

If the product to be returned is contaminated or is possibly contaminated with substances that are harmful to humans, for safety reasons, please contact SMC beforehand and then employ a specialist cleaning company to decontaminate the product. After the decontamination prescribed above has been carried out, submit a Product Return Request Sheet or the Detoxification/Decontamination Certificate to SMC and await SMC's approval and further instructions before attempting to return the item.

Please refer to the International Chemical Safety Cards (ICSC) for a list of harmful substances.

If you have any further questions, please don't hesitate to contact your SMC sales representative.





## ITV Series

# Specific Product Precautions 3

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For F.R.L. units precautions, refer to the “Handling Precautions for SMC Products” and the “Operation Manual” on the SMC website: <https://www.smc.eu>

### ITV1000/2000/3000/209 Series Precautions

#### Piping


#### Warning

1. When screwing piping into a component, tighten within the recommended tightening torque range while holding the female thread side.

If the tightening torque is insufficient, looseness or sealing failure may occur. On the other hand, excess tightening torque can result in damage to the threads. Furthermore, tightening without holding the female thread side can result in damage due to the excess force that is applied directly to the piping bracket.


Recommended tightening torque range: N·m

Connection thread	1/8	1/4	3/8	1/2
Torque	3 to 5	8 to 12	15 to 20	20 to 25



2. Avoid excessive torsional moment and bending moment other than those caused by the equipment's own weight, as failure to do so may result in damage.

Support external piping separately.



3. Piping materials which lack flexibility, such as steel tube piping, are prone to being affected by excess moment loads and vibrations from the piping side. Use flexible tubing in between to avoid such effects.

#### Caution


##### 1. Preparation before piping

Before piping is connected, it should be thoroughly blown out with air (flushing) or washed to remove chips, cutting oil, and other debris from inside the pipe.

If chips, sealing material, or other debris enter into this product, the solenoid valve may buzz or the outlet pressure may not be output properly.

##### 2. Winding of sealant tape

When screwing piping or fittings into ports, ensure that chips from the pipe threads or sealing material do not enter the piping. Also, if sealant tape is used, leave 1.5 to 2 thread ridges exposed at the end of the threads.



#### Operating Environment

#### Warning

1. Do not use in atmospheres containing corrosive gases, chemicals, sea water, or where there is direct contact with any of these.
2. Please contact SMC regarding use at power stations or in instrumentation applications.

#### Caution

1. When used in locations where the body of the product is exposed to water, water vapor, dust, etc., there is a possibility that moisture or dust could enter the body through the EXH (solenoid) ports, thereby causing problems.
2. To prevent this, simply install tubing to each port, using the fittings, and extend the tubing so that the other end is in a location where no water splash, etc., occurs. Make sure not to bend or block the I.D. of the tubing as this will have a detrimental effect on the pressure control.
3. Do not use in places subject to heavy vibration and/or impact.
4. The product should not be exposed to prolonged sunlight. Use a protective cover if this is unavoidable.
5. Remove any sources of excessive heat.
6. In locations where there is contact with water, oil, weld spatter, etc., take suitable protective measures.

#### Air Supply

#### Warning

1. Please contact SMC when using the product in an application using a fluid other than compressed air.
2. Do not use compressed air that contains chemicals, synthetic oils that include organic solvents, salt, corrosive gases, etc., as doing so may result in a malfunction.

#### Caution

1. Install an air filter near this product on the supply side. Select an air filter with a filtration size of 5 μm or smaller.
2. Compressed air that contains a large amount of drainage can cause the malfunction of this product and other pneumatic equipment. Therefore, take appropriate measures to ensure air quality, such as providing an aftercooler, air dryer, or water separator.
3. If excessive carbon dust is generated by the compressor, it may adhere to the inside of this product and cause it to malfunction.

Refer to the “SMC Air Preparation System” for further details on compressed air quality.





## ITV Series

# Specific Product Precautions 4

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For F.R.L. units precautions, refer to the “Handling Precautions for SMC Products” and the “Operation Manual” on the SMC website: <https://www.smc.eu>

### ITV1000/2000/3000/209 Series Precautions

#### Handling

#### ⚠ Caution

1. Do not use a lubricator on the supply side of this product, as doing so may result in a malfunction. When lubrication of terminal equipment is necessary, connect a lubricator on the output side of this equipment.
2. If electric power is shut off while pressure is being applied, pressure will be retained on the output side. However, this output pressure is held only temporarily and is not guaranteed. If exhausting of this pressure is desired, shut off the power after reducing the set pressure, and discharge the air using a residual pressure exhaust valve, etc.
3. If the power to this product is cut off due to a power failure, etc., when it is in a controlled state, output pressure will be retained temporarily. Handle carefully when operating with output pressure released to the atmosphere, as air will continue to flow out.
4. If supply pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and a humming noise may be generated. Since the life of the product may be shortened, shut off the power supply also when supply pressure is shut off.
5. The setting side pressure cannot be completely released from this product in the range below 0.005 MPa (or -1.3 kPa for vacuum models). In cases where the pressure needs to be reduced completely to 0 MPa, install a 3-port valve, etc., on the setting side to discharge the residual pressure.
6. This product is adjusted for each specification at the time of shipment from the factory. Avoid careless disassembly or removal of parts, as failure to do so may result in a malfunction.
7. The optional cable connector is a 4-wire type. When the monitor output (analogue output or switch output) is not being used, keep it from touching the other wires as doing so may result in a malfunction.
8. When connecting the cable to this product, turn the lock ring of the cable. If a portion other than the lock ring of the cable is turned, it may damage the connector on the body. Turn the lock ring by hand without using a tool.
9. The right angle cable does not rotate and is limited to only one entry direction. If the right angle cable is rotated forcibly, the cable may be broken or damaged, or may damage the connector on the body.
10. Take the following steps to avoid malfunction due to noise.
  - 1) Remove power supply noise during operation by installing a line filter, etc., in the AC power line.
  - 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors, power lines, etc.
  - 3) Be sure to implement protective measures against load surge for induction loads (solenoid valves, relays, etc.).
11. Due to the large volume of the output side, a loud exhaust noise will be produced when being used for the purpose of a relief function. Therefore, install a silencer (SMC AN20 or AN40 series) on the exhaust port (EXH port). The port sizes are Rc1/8, Rc1/4, and Rc1/2.
12. Specifications on pages 14 and 47 are in case of static environment. Pressure may fluctuate when air is consumed at the output side.

#### Handling


#### ⚠ Caution

13. For details on the handling of this product, refer to the operation manual which is included with the product.
14. This product does not have a shut-off valve function. If air pressure is supplied without electric power being applied, output pressure may increase to the pressure equivalent of the supply pressure. Operate the system to shut off the supply pressure when not operating the product.
15. The solenoid valves built into this product are consumables. Perform periodic maintenance in environments where the solenoid valves are operated at a high frequency. The parts can be replaced with a solenoid valve assembly. Please contact SMC for the part number.
16. In locations where the body is exposed to water, dust, etc., there is a possibility that moisture or dust could enter the body through the solenoid valve EXH port. Mount a fitting and tube onto the solenoid valve EXH port and run the tube to a location not exposed to moisture, dust, etc.

#### Design and Selection

#### ⚠ Caution

1. Use the following UL approved products for DC power supply combinations.
  - (1) Limited voltage current circuit in accordance with UL 508  
A circuit in which power is supplied by the secondary coil of a transformer that meets the following conditions
    - Max. voltage (with no load): 30 Vrms (42.4 V peak) or less
    - Max. current:
      - (1) 8 A or less (including when short circuited)
      - (2) limited by circuit protector (such as fuse) with the following ratings
  - (2) A circuit (class 2 circuit) with max. 30 Vrms (42.4 V peak) or less, and a power supply consisting of a class 2 power supply unit conforming to UL1310, or a class 2 transformer confirming to UL1585
2. Operate these products only within the specified voltage.  
Using voltages beyond the specified levels could result in faults or malfunctions.
3. Use 0 V as the baseline for the power supplied to the unit for output, control, and input.



4. Each product needs to be powered by one power supply unit.  
The wiring of this product has the same common between the GND for power and the signals; there is a possibility that a wrong current occurs and prevents a proper operation if one power supply unit controls multiple electro-pneumatic regulators.
5. Please contact SMC for the usage when the downstream side is released to atmosphere.  
This product is a pressure controller. The downstream side being released to atmosphere makes the inlet valve full open, allowing a large amount of atmosphere flow into the body. Please contact SMC for the appropriate usage when you use the product under such condition since the product may not meet the specification or the life of the product may be shortened.



## ITV Series

# Specific Product Precautions 5



Be sure to read this before handling the products. Refer to the back cover for safety instructions. For F.R.L. units precautions, refer to the “Handling Precautions for SMC Products” and the “Operation Manual” on the SMC website: <https://www.smc.eu>

### ITV1000/2000/3000/209 Series Precautions

#### Wiring

## Caution

Connect the cable to the connector on the body with the wiring arranged as shown below. Proceed carefully, as incorrect wiring can result in damage. Further, use DC power with sufficient capacity and a low ripple.



#### Current Signal Type Voltage Signal Type


1	Brown	Power supply
2	White	Input signal
3	Blue	GND (COMMON)
4	Black	Monitor output

#### Preset Input Type


1	Brown	Power supply
2	White	Input signal 1
3	Blue	GND (COMMON)
4	Black	Input signal 2

#### IO-Link


1	Brown	Power supply
2	White	No connection
3	Blue	GND
4	Black	IO-Link communication data



#### CC-Link



#### PROFIBUS DP



#### DeviceNet™, RS-232C, 16 points preset

Pin no.	IN/OUT communication connector				Signal connector
	CC-Link	DeviceNet®	PROFIBUS DP	RS-232C	16 points preset
1	SLD [-]	DRAIN [-]	No connection	No connection	Input signal 1 [Brown]
2	DB [White]	V+ [Red]	RxD/TxD-N [Green]	TxD [White]	Input signal 2 [White]
3	DG [Yellow]	V- [Black]	No connection	RxD [Blue]	Input signal 3 [Blue]
4	DA [Blue]	CAN_H [White]	RxD/TxD-P [Red]	GND [Black]	Input signal 4 [Black]
5	No connection	CAN_L [Blue]	No connection	No connection	Common [Grey]

Pin no.	Power supply connector				
	CC-Link	DeviceNet®	PROFIBUS DP	RS-232C	16 points preset
1 [Brown]	Vcc	Vcc	Vcc	Vcc	Vcc
2 [White]	FG	Cannot connect	FG	No connection	No connection
3 [Blue]	GND	GND	GND	GND	GND
4 [Black]	No connection	Cannot connect	No connection	FG	Monitor output

\*1 The cable is also available in a right angle type. (Communication cable: straight type only)  
A right angle type connector is attached facing left (toward the SUP port). On communication models, the connector faces backward (toward the EXH port). Do not attempt to rotate, as the connector does not turn.


\* The indicated wire colours are when a cable connector made by SMC is used.  
\* Perform the wiring so that no electric potential difference occurs between GND of the power supply and GND of the communication section. If any electric potential difference occurs, this may cause the internal parts to burn out.

#### Knock-down connectors \* Order separately.

Application Part no.	CC-Link compatibility		DeviceNet® compatibility		PROFIBUS DP compatibility		
	Plug PCA-1075526	Socket PCA-1075527	Plug PCA-1075528	Socket PCA-1075529	Terminal plug PCA-1557675	Plug PCA-1075530	Socket PCA-1075531
							Terminal plug PCA-1557727


#### Wiring diagrams

##### Current signal type




Vs : Power supply 24 VDC  
12 to 15 VDC  
A : Input signal 4 to 20 mA DC  
0 to 20 mA DC

##### Voltage signal type




Vs : Power supply 24 VDC  
12 to 15 VDC  
Vin : Input signal 0 to 5 VDC  
0 to 10 VDC

##### 4 points preset input type



Vs : Power supply 24 VDC  
12 to 15 VDC  
(Negative common)

##### 16 points preset input type



Vs : Power supply 24 VDC (No polarity)

One of the preset pressures P1 through P4 is selected by the ON/OFF combination of S1 and S2.

S1	OFF	ON	OFF	ON	OFF
S2	OFF	OFF	ON	ON	OFF
S3	OFF	OFF	OFF	OFF	ON
S4	OFF	OFF	OFF	OFF	OFF
Preset pressure	P01	P02	P03	P04	P05

ON	OFF	ON
OFF	ON	ON
ON	ON	ON
ON	ON	ON
P14	P15	P16

\* For safety reasons, it is recommended that one of the preset pressures be set to 0 MPa.  
\* Preset pressures are set based on the min. unit for output display.

MPa	kgf/cm <sup>2</sup>	bar	psi	kPa
0.001	0.01	0.01	0.1	1

\* Note that this is 1 psi for 130 psi types.

#### Trademark

DeviceNet® is a trademark of ODVA, Inc.



## ITV Series

# Specific Product Precautions 6

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For F.R.L. units precautions, refer to the “Handling Precautions for SMC Products” and the “Operation Manual” on the SMC website: <https://www.smc.eu>

### ITV1000/2000/3000/209□ Series Precautions

#### Wiring


##### 10-bit digital input type

Wire colour	Signal name
Pink-Black 2	Power supply (24 VDC)
Green-Black 2	Power supply (GND)
Blue	Signal common (No polarity)
Blue-Black 2	MSB 10 bit
Grey-Black 1	9 bit
Orange-Black 1	8 bit
Green-Black 1	7 bit
Pink-Black 1	6 bit
Blue-Black 1	5 bit
Grey	4 bit
Orange	3 bit
Green	2 bit
Pink	LSB 1 bit


\* The wire colour is shown for when an option cable is used.

#### Monitor output wiring diagrams


##### Analogue output: Voltage type




##### Analogue output: Current type (Sink type)



##### Switch output: NPN type




##### Switch output: PNP type



\*1 When 80 mADC or more is applied, detecting device for overcurrent starts activating and then emits an error signal. (Error number “5”)

#### Monitor output (analogue output) characteristics diagram



#### Set Pressure Range

The set pressure range, by unit of standard measured pressure, is shown in the table below.

Set pressure range, by unit of standard measured pressure

Unit	Set pressure range			
	ITV□01□	ITV□03□	ITV□05□	ITV209□
MPa	0.005 to 0.1	0.005 to 0.5	0.005 to 0.9	—
kgf/cm <sup>2</sup>	0.05 to 1	0.05 to 5	0.05 to 9	—
bar	0.05 to 1	0.05 to 5	0.05 to 9	—
psi	0.7 to 15	0.7 to 70	0.7 to 130	—
kPa	5 to 100	5 to 500	5 to 900	−1.3 to −80

#### CE/UKCA Marking

##### • ITV0000 Series

Model	Ferrite core necessity	Recommended power supply cable
ITV0000-□□	Unnecessary	M8-4DSX3MG4 (Straight type) P398000-501-2 (Right angle type)

\* Recommended power supply cable length is 3 m. (P398000-501-2 is 2 m.)  
If any other length is desired, please contact SMC.

##### • ITV1000/2000/3000 Series

Model	Ferrite core necessity	Recommended power supply cable	
ITV□□-□□	Unnecessary	—	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
ITV□□-52□ ITV□□-53□		Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
		Signal	P398020-502-3 (Straight type) P398020-503-3 (Right angle type)
ITV□□-60□		—	INI-398-0-59 (Straight type)
*1, *2 ITV□□-CC□		Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
		Communication	PCA-1567720 (Socket type) PCA-1567717 (Plug type)
*1, *3 ITV□□-DE□		Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
		Communication	PCA-1557633 (Socket type) PCA-1557646 (Plug type)
*1, *3 ITV□□-PR□		Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
		Communication	PCA-1557688 (Socket type) PCA-1557691 (Plug type)
ITV□□-RC□		Power	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)
		Communication	P398020-502-3 (Straight type) P398020-503-3 (Right angle type)
ITV□□-IL□		—	P398020-500-3 (Straight type) P398020-501-3 (Right angle type)

\*1 Even when the “with cable connector” type is selected, the communication connector is not included. Refer to the catalogue [M8/M12 Connector] CAT. ES100-73 for the details of the communication cable.

\*2 For CC-Link compatible products, a dedicated Bus adapter is included with the product.

\*3 For DeviceNet® compatible products, and PROFIBUS DP compatible products, a T-branch connector is not included with the product.

\* Recommended power supply cable length is 3 m. If any other length is desired, please contact SMC.

#### Return of Product

### Warning

If the product to be returned is contaminated or is possibly contaminated with substances that are harmful to humans, for safety reasons, please contact SMC beforehand and then employ a specialist cleaning company to decontaminate the product. After the decontamination prescribed above has been carried out, submit a Product Return Request Sheet or the Detoxification/Decontamination Certificate to SMC and await SMC's approval and further instructions before attempting to return the item. Please refer to the International Chemical Safety Cards (ICSC) for a list of harmful substances.

If you have any further questions, please don't hesitate to contact your SMC sales representative.



# Specific Product Precautions 7

Be sure to read this before handling the products. Refer to the back cover for safety instructions. For F.R.L. units precautions, refer to the “Handling Precautions for SMC Products” and the “Operation Manual” on the SMC website: <https://www.smc.eu>

### ITV009□/209□ Series Precautions

#### Handling

#### Caution

1. Connect the vacuum pump to the port, which is labeled “VAC.”
2. Pressure adjustment changes from “atmospheric pressure to vacuum pressure” when the input signal is increased, and from “vacuum pressure to atmospheric pressure” when the input signal is decreased.
3. When adjusting the vacuum pressure, be careful not to block the atmospheric pressure inlet port labeled “ATM.”
4. Since this product is designed exclusively for use with negative pressure, be careful not to apply positive pressure in error.
5. In cases where the vacuum pump being used has a relatively small capacity, or the piping has a small inside diameter, etc., large variations in the set pressure (the range of pressure variation when changing from no flow to flow state) may appear. In this situation, the vacuum pump or the piping should be changed. In cases where it is not practical to change the vacuum pump, install a capacity tank (volume depending on the operating conditions) on the VAC side.
6. The vacuum pressure response time after a change in the input signal is influenced by the internal volume on the setting side (including piping). Since the capacity of the vacuum pump also influences the response time, give careful consideration to these points before operation.
7. If the electric power is shut off when in a control state, the pressure on the setting side will go into a holding condition. However, this setting side pressure will be held only temporarily and is not guaranteed. In addition, when atmospheric pressure is desired, shut off the power after reducing the set pressure, and then introduce atmospheric pressure by using a vacuum release valve, etc.
8. If the power for this product is cut off by a power failure, etc., when it is in a controlled state, the setting side pressure will be held temporarily. Further, if operated without sealing the setting side so that atmospheric air is sucked in, handle with care as air will continue to be sucked in.
9. If the VAC side pressure to this product is interrupted while the power is still on, the internal solenoid valve will continue to operate and may cause a humming noise. Since this may shorten the life of the product, be sure to shut off the power when the VAC side pressure is shut off.
10. The setting side pressure cannot be completely released from this product in the range below  $-1.3$  kPa. In cases where the pressure needs to be reduced completely to 0 kPa, install a 3-port valve, etc., on the setting side to discharge the residual pressure.
11. This product is adjusted for each specification at the factory before shipment. Avoid careless disassembly or removal of parts, as this can result in failure.

#### Handling

#### Caution

12. The optional cable connector is a 4-wire type. When the monitor output (analogue output, switch output) is not being used, keep it from touching the other wires, as doing so may result in a malfunction.
13. Use caution that the right angle cable does not rotate and is limited to only one entry direction.
14. Take the following steps to avoid malfunction due to noise.
  - 1) Remove power supply noise during operation by installing a line filter, etc., in the AC power line.
  - 2) For avoiding the influence of noise or static electricity, install this product and its wiring as far as possible from strong electric fields such as those of motors, power lines, etc.
  - 3) Be sure to implement protective measures against load surge for induction loads (solenoid valves, relays, etc.).
15. Refer to the operation manual included with the product for details on its handling.

#### Return of Product

#### Warning

If the product to be returned is contaminated or is possibly contaminated with substances that are harmful to humans, for safety reasons, please contact SMC beforehand and then employ a specialist cleaning company to decontaminate the product. After the decontamination prescribed above has been carried out, submit a Product Return Request Sheet or the Detoxification/Decontamination Certificate to SMC and await SMC's approval and further instructions before attempting to return the item.

Please refer to the International Chemical Safety Cards (ICSC) for a list of harmful substances.

If you have any further questions, please don't hesitate to contact your SMC sales representative.




■ Trademark

DeviceNet® is a registered trademark of ODVA, Inc.



## Safety Instructions

These safety instructions are intended to prevent hazardous situations and/or equipment damage. These instructions indicate the level of potential hazard with the labels of “Caution,” “Warning” or “Danger.” They are all important notes for safety and must be followed in addition to International Standards (ISO/IEC)<sup>1)</sup>, and other safety regulations.

-  **Caution:** **Caution** indicates a hazard with a low level of risk which, if not avoided, could result in minor or moderate injury.
-  **Warning:** **Warning** indicates a hazard with a medium level of risk which, if not avoided, could result in death or serious injury.
-  **Danger:** **Danger** indicates a hazard with a high level of risk which, if not avoided, will result in death or serious injury.

- 1) ISO 4414: Pneumatic fluid power – General rules relating to systems.  
ISO 4413: Hydraulic fluid power – General rules relating to systems.  
IEC 60204-1: Safety of machinery – Electrical equipment of machines.  
(Part 1: General requirements)  
ISO 10218-1: Manipulating industrial robots - Safety.  
etc.

## Warning

### 1. The compatibility of the product is the responsibility of the person who designs the equipment or decides its specifications.

Since the product specified here is used under various operating conditions, its compatibility with specific equipment must be decided by the person who designs the equipment or decides its specifications based on necessary analysis and test results. The expected performance and safety assurance of the equipment will be the responsibility of the person who has determined its compatibility with the product. This person should also continuously review all specifications of the product referring to its latest catalogue information, with a view to giving due consideration to any possibility of equipment failure when configuring the equipment.

### 2. Only personnel with appropriate training should operate machinery and equipment.

The product specified here may become unsafe if handled incorrectly. The assembly, operation and maintenance of machines or equipment including our products must be performed by an operator who is appropriately trained and experienced.

### 3. Do not service or attempt to remove product and machinery/equipment until safety is confirmed.

1. The inspection and maintenance of machinery/equipment should only be performed after measures to prevent falling or runaway of the driven objects have been confirmed.
2. When the product is to be removed, confirm that the safety measures as mentioned above are implemented and the power from any appropriate source is cut, and read and understand the specific product precautions of all relevant products carefully.
3. Before machinery/equipment is restarted, take measures to prevent unexpected operation and malfunction.

### 4. Contact SMC beforehand and take special consideration of safety measures if the product is to be used in any of the following conditions.

1. Conditions and environments outside of the given specifications, or use outdoors or in a place exposed to direct sunlight.
2. Installation on equipment in conjunction with atomic energy, railways, air navigation, space, shipping, vehicles, military, medical treatment, combustion and recreation, or equipment in contact with food and beverages, emergency stop circuits, clutch and brake circuits in press applications, safety equipment or other applications unsuitable for the standard specifications described in the product catalogue.
3. An application which could have negative effects on people, property, or animals requiring special safety analysis.
4. Use in an interlock circuit, which requires the provision of double interlock for possible failure by using a mechanical protective function, and periodical checks to confirm proper operation.

## Caution

### 1. The product is provided for use in manufacturing industries.

The product herein described is basically provided for peaceful use in manufacturing industries.  
If considering using the product in other industries, consult SMC beforehand and exchange specifications or a contract if necessary.  
If anything is unclear, contact your nearest sales branch.

## Limited warranty and Disclaimer/Compliance Requirements

The product used is subject to the following “Limited warranty and Disclaimer” and “Compliance Requirements”. Read and accept them before using the product.

### Limited warranty and Disclaimer

1. The warranty period of the product is 1 year in service or 1.5 years after the product is delivered, whichever is first.<sup>2)</sup> Also, the product may have specified durability, running distance or replacement parts. Please consult your nearest sales branch.
  2. For any failure or damage reported within the warranty period which is clearly our responsibility, a replacement product or necessary parts will be provided. This limited warranty applies only to our product independently, and not to any other damage incurred due to the failure of the product.
  3. Prior to using SMC products, please read and understand the warranty terms and disclaimers noted in the specified catalogue for the particular products.
- 2) Vacuum pads are excluded from this 1 year warranty.  
A vacuum pad is a consumable part, so it is warranted for a year after it is delivered. Also, even within the warranty period, the wear of a product due to the use of the vacuum pad or failure due to the deterioration of rubber material are not covered by the limited warranty.

### Compliance Requirements

1. The use of SMC products with production equipment for the manufacture of weapons of mass destruction (WMD) or any other weapon is strictly prohibited.
2. The exports of SMC products or technology from one country to another are governed by the relevant security laws and regulations of the countries involved in the transaction. Prior to the shipment of a SMC product to another country, assure that all local rules governing that export are known and followed.

## Caution

### SMC products are not intended for use as instruments for legal metrology.

Measurement instruments that SMC manufactures or sells have not been qualified by type approval tests relevant to the metrology (measurement) laws of each country.  
Therefore, SMC products cannot be used for business or certification ordained by the metrology (measurement) laws of each country.

## Safety Instructions

Be sure to read “Handling Precautions for SMC Products” (M-E03-3) before using.

## Revision History

<b>Edition G</b>	<ul style="list-style-type: none"> <li>- IO-Link compatible products have been added.</li> <li>- An analogue output, current type (source type) has been added to the made-to-order products.</li> <li>- Cable connector specifications have been added to the accessories.</li> <li>- Number of pages has been increased from 52 to 64.</li> </ul>	<b>ZU</b>
------------------	---	-----------

## SMC Corporation (Europe)

<b>Austria</b>	+43 (0)2262622800	www.smc.at	office@smc.at
<b>Belgium</b>	+32 (0)33551464	www.smc.be	info@smc.be
<b>Bulgaria</b>	+359 (0)2807670	www.smc.bg	office@smc.bg
<b>Croatia</b>	+385 (0)13707288	www.smc.hr	office@smc.hr
<b>Czech Republic</b>	+420 541424611	www.smc.cz	office@smc.cz
<b>Denmark</b>	+45 70252900	www.smc.dk.com	smc@smcdk.com
<b>Estonia</b>	+372 6510370	www.smc.pneumatics.ee	smc@info@smcee.ee
<b>Finland</b>	+358 207513513	www.smc.fi	smc@info@smc.fi
<b>France</b>	+33 (0)164761000	www.smc-france.fr	info@smc-france.fr
<b>Germany</b>	+49 (0)61034020	www.smc.de	info@smc.de
<b>Greece</b>	+30 210 2717265	www.smc.hellas.gr	sales@smchellas.gr
<b>Hungary</b>	+36 23513000	www.smc.hu	office@smc.hu
<b>Ireland</b>	+353 (0)14039000	www.smcautomation.ie	sales@smcautomation.ie
<b>Italy</b>	+39 03990691	www.smcitalia.it	mailbox@smcitalia.it
<b>Latvia</b>	+371 67817700	www.smc.lv	info@smc.lv

<b>Lithuania</b>	+370 5 2308118	www.smc.lt	info@smc.lt
<b>Netherlands</b>	+31 (0)205318888	www.smc.nl	info@smc.nl
<b>Norway</b>	+47 67129020	www.smc-norge.no	post@smc-norge.no
<b>Poland</b>	+48 222119600	www.smc.pl	office@smc.pl
<b>Portugal</b>	+351 214724500	www.smc.eu	apoioclientept@smc.smces.es
<b>Romania</b>	+40 213205111	www.smcromania.ro	smcromania@smcromania.ro
<b>Russia</b>	+7 (812)3036600	www.smc.eu	sales@smcru.com
<b>Slovakia</b>	+421 (0)413213212	www.smc.sk	office@smc.sk
<b>Slovenia</b>	+386 (0)73885412	www.smc.si	office@smc.si
<b>Spain</b>	+34 945184100	www.smc.eu	post@smc.smces.es
<b>Sweden</b>	+46 (0)86031240	www.smc.nu	smc@smc.nu
<b>Switzerland</b>	+41 (0)523963131	www.smc.ch	info@smc.ch
<b>Turkey</b>	+90 212 489 0 440	www.smc.pnomatik.com.tr	info@smcpnomatik.com.tr
<b>UK</b>	+44 (0)845 121 5122	www.smc.uk	sales@smc.uk

<b>South Africa</b>	+27 10 900 1233	www.smcza.co.za	zasales@smcza.co.za
---------------------	-----------------	-----------------	---------------------