

Certificate of Compliance

Certificate: 165850-2500002106 (LR 14385)

Project: 2500002106

Date Issued: October 25, 1999

Issued to: Eh-Schrack Components AG
Schrackstrasse 1
A-3830 Waidhofen an der Thaya
Austria
Attention: Mr. Martin Bauer

The products listed below are eligible to bear the CSA Mark shown



Issued by: D. Bairos, P.Eng.

Signature: 

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays, Series PT... with suffixes, open type with dust cover, 2, 3 and 4 pole, magnetically operated relays provided with double throw contacts (NO, NC) with socket mount and pcb types; rated as follows:

Maximum Voltage	Load	Contact Ratings		No. of Operations
		(NO)	(NC)	
150 Vac	Resistive	12 A (2 NO)	12 A (2 NC)	100,000
250 Vac	Resistive	10 A (2 NO)	10 A (2 NC)	100,000
250 Vac	Resistive	10 A (3 NO)	10 A (3 NC)	100,000
250 Vac	Resistive	6 A (4 NO)	6 A (4 NC)	100,000

Coil - 6 Vdc to 220 Vdc max or 6 Vac to 230 Vac max..

Notes:

1. Open type devices certified as components for use in assemblies where the suitability of the combination is to be determined in the end product evaluation.
2. Ambient temperature - 70 °C max. for relays without sockets and 50°C max for relays with EH Schrack ES 15 relay sockets
3. The total connected load shall not exceed 20 A at 151-300 V.
4. Suffixes denote mechanical and electrical variations.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14 - Industrial Control Equipment



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 165850 -2500002106(LR14385)

Project: 2500002106

Issued to: **Eh-Schrack Components AG**
Schrackstrasse 1
A-3830 WAIDHOFEN AN DER THAYA
Austria
Attention: Mr. Martin Bauer

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Issued By: D. Bairos, P. Eng.

Signature: 

Product Certification History

Revision	Date	Description
2500002106	Oct 25/99	Original Certification.