

Certificate of Compliance

Certificate: 1198742 (LR 12400-385)

Master Contract: 154685

Project: 1198742

Date Issued: May 3, 2001

Issued to: WEIDMÜLLER LTD.
 10 Spy Court
 Markham, ON L3R 5H6
 CANADA

The products listed below are eligible to bear the CSA Mark shown



Issued by: G. Foulem, E.I.T.

G. Foulem

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Electronic Relay Unit, open type, Cat. No. MCZ R, supply voltage 24 Vac/dc, 120 Vac, 230 Vac, output 6 A 24 Vac/dc
- Electronic Converter Unit, open type, Cat. No. MCZ CCC, input rating 15 Vdc, 20mA, output rating 10 Vdc, 20 mA
- Opto coupler Unit, open type, Cat. No. MCZ O

<u>Supply Voltage</u>	<u>Output</u>
24 V ac/dc	48 Vdc, 20 mA
24 V ac/dc	24 Vdc, 2 A
5-48 Vdc	5-48 Vdc, 100 mA
24 Vdc	5 Vdc, 8 mA
120 V ac/dc	48 Vdc, 50 mA
230 Vac	48 Vdc, 20mA

- Analog PT100 Unit, open type, Cat. No. MCZ PT100/3, supply voltage 24 Vdc, output 4...20 mA
- Time Delay Off Unit, open type, Cat No. MCZ TO, supply voltage 24 Vdc, output 48 Vdc 20 mA 50-150 msec time delay
- Limiting Value Unit, open type, Cat. No. MCZ SC, supply voltage 24 Vdc, input 0...10 V, output 2x 50 mA.

Certificate: 1198742



Master Contract: 154685

Project: 1198742

Date: May 3, 2001

Notes:

1. The catalogue numbers may be completed by suffixes indicating the type of terminal, mounting foot and color of insulating material.
2. Certified for use only in other equipment where the acceptability of the combination is to be determined by CSA International.

APPLICABLE STANDARDS

The product, as described in this report, complies with:

- CAN/CSA-C22.2 No. 0-M91 - General Requirements - Canadian Electrical Code, Part II
- CAN/CSA-C22.2 No. 14-95 - Industrial Control Equipment