



# Certificate of Compliance

Certificate Number: LR 12730-357  
KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

Issued To: Siemens AG  
Abt. ASI 2 GWA TPA  
Werner von Siemens  
Strasse 48  
92220 AMBERG  
Germany

*The products listed below are eligible to bear the CSA Mark.*

Issued By: J. Pankowski  
CSA Montreal

Signature

## PRODUCTS

Contactors, open types, Series 3RT1024, 3RT1025, 3RT1026, with the following ratings:

Voltage	3RT1024	
	1-ph	3-ph
115 V	1 hp	--
200 V	2 hp	3 hp
230/240 V	2 hp	3 hp
460/480 V	--	7 1/2 hp
575 V	--	10 hp
600 V	--	10 hp



## Certificate of Compliance

Certificate Number: LR 12730-357  
KEMA Ref. 97.3651

Revision: LR 12730-383

Date Issued: September 24, 1997

3RT1025		
Voltage	1-ph	3-ph
115 V	1 hp	--
200 V	2 hp	5 hp
230/240 V	2 hp	5 hp
460/480 V	--	10 hp
575 V	--	15 hp
600 V	--	15 hp

3RT1026		
Voltage	1-ph	3-ph
115 V	2 hp	--
200 V	3 hp	7 1/2 hp
230/240 V	3 hp	7 1/2 hp
460/480 V	--	15 hp
575 V	--	20 hp
600 V	--	20 hp

Main Contacts: General Purpose Rating  
600 Vac, 35 A

Auxiliary Contacts: A600, Q600, 240 V, 10 A general purpose

Coil Ratings: 24 through 600 Vac  
12 through 250 Vdc

### Notes:

- 1 The type designations may be completed with suffixes indicating contact arrangements, terminal design, mounting etc.
- 2 Certified as component for use only in Certified equipment where the acceptability of the combination is to be determined by the Canadian Standards Association.

### APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0 - M91 - General Requirements  
" " " " 14 - 95 - Industrial Control Equipment