

## **EU Declaration of Conformity**



No: RML 111 Rev. E

We,

Rosemount Measurement Limited 158 Edinburgh Avenue, Slough, Berkshire, SL1 4UE United Kingdom

declare under our sole responsibility that the product,

# Mobrey MSP Series Ultrasonic Level Transmitter (MSP422, MSP400RH, MSP900GH)

manufactured by,

Rosemount Measurement Limited 158 Edinburgh Avenue, Slough, Berkshire, SL1 4UE United Kingdom

to which this declaration relates, is in conformity with the provisions of the European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community notified body certification, as shown in the attached schedule.

(signature)

Global Approvals Manager

(function)

David J Ross-Hamilton

4/20/2016

(name)

(date of issue)





#### **EU Declaration of Conformity**

No: RML 111 Rev. E

EMC Directive (2014/30/EU)

Model MSP400RH-\*\*\*, MSP900GH-\*\*\*

Harmonized Standards: EN 61326-1:2013, EN 61326-2.3:2013

Model MSP422-\*\*\*

Harmonized Standards: EN 61326-1:2013, EN 61326-2.3:2013 Class A (Industrial Radiated Emission limits)

ATEX Directive (2014/34/EU)

Model MSP900GH-\*\*\*

Sira 02ATEX2405X – Intrinsically safe

Equipment Group II, Category 1 G (Ex ia IIC T4/T6 Ga) Harmonized Standards: EN 60079-11:2012, EN 60079-26:2007

Other Standards Used: IEC 60079-0:2011

(Minor variations in design to suit the application and/or mounting requirements are identified by alpha/numeric characters where indicated \* above)

ROSEMOUNT





### **EU Declaration of Conformity**

No: RML 111 Rev. E

#### **ATEX Notified Body**

**Baseefa** [Notified Body Number: 1180] Rockhead Business Park, Staden Lane Buxton, Derbyshire, SK17 9RZ, United Kingdom

#### **ATEX Notified Body for Quality Assurance**

**Sira Certification Service** [Notified Body Number: 0518] Unit 6, Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

